



Certificate of Compliance

Certificate: 70171762

Master Contract: 213842

Project: 70171762

Date Issued: 2018-02-21

Issued to: UWT GmbH
Westendstrasse 5
Betzigau, 87488
GERMANY
Attention:

The products listed below are eligible to bear the CSA Mark shown



Issued by: Sam Zaffino
Sam Zaffino

PRODUCTS

CLASS - C225205 - PROCESS CONTROL EQUIPMENT

CLASS - C225285 - PROCESS CONTROL EQUIPMENT-Certified to US Standards

Capanivo Series CN7000, Type CN7100 Capacitance Level Switches, Type 4/IP65/IP68 enclosure, conduit connected, Rated Input 12 to 33Vdc, 20mA max; Pollution Degree 4, Installation Category I.

/Fully synthetic version: Relay contacts rated: 60Vdc/30Vac, 1A max and limited to 35Vdc/16Vac, 1A max in wet locations, ambient -10 to 85°C.

Integral cable version: Solid State Switch rated 30Vdc, 82mA max; ambient -30 to 85°C.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 61010-1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

ISA S82.02.01 2nd (IEC 61010-1 Mod) - Safety Standards for Electrical and Electronic Test, Measuring, Controlling and Related Equipment - General Requirements.

UL 61010-1 2nd - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements



Supplement to Certificate of Compliance

Certificate: 70171762

Master Contract: 213842

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70171762	2018-02-21	Transfer of report -1981962 to UWT with update on model nos., drawings, etc