

PD6907 Ex-Proof & I.S. Loop-Powered Feet & Inches Meter

Instruction Manual



ProtEX+

SP Ex IECEx CE

CAP TOUCH™

MeterView XL

USB Install

- Fully-Approved Explosion-Proof & Intrinsically Safe Loop-Powered Feet & Inches Meters
- 4-20 mA Input Displayed with $\pm 0.02\%$ of Full-Scale Accuracy
- 1.5 Volt Drop (4.7 Volt Drop with Backlight)
- 0.7" (17.0 mm) 5 Digits 7-Segment, FT-IN & Fractions Top Display
- 0.4" (10.2 mm) 8 Alphanumeric 14-Segment Characters Bottom Display
- Displays Level in Feet & Inches up to 999 Feet, 11 & 15/16 Inches
- Display Input in Two Different Scales Simultaneously - Great for Level
- 20-Segment Bargraph Standard
- Display Mountable at 0°, 90°, 180°, & 270°
- CapTouch Through-Glass Button Programming with Normal and Delayed Modes
- Loop-Powered Backlight with Red Backlight for Alarm Conditions
- (2) Open Collector Outputs Standard; Assignable to Pulse, Alarm, Timer, or Stopwatch
- (2) Optional Loop-Powered Solid-State Relays; Assignable to Alarm, Control, Timer, or Stopwatch
- Stopwatch & Timer Functions to Drive Relays & Open Collectors
- Optional Isolated 4-20 mA Analog Output
- Relay Pump Alternation Based on Level and Runtime
- Display Relay Runtime & Cycle Count via Relay Info Menu
- Round Horizontal Tank Function; Just Enter Diameter & Length
- 32-Point Linearization
- Free PC-Based MeterView XL USB Programming Software
- HART® Protocol Transparent
- Enable and Disable Backlight from Menu
- Operating Temperature Range: -40 to 75°C (-40 to 167°F)
- Installation Temperature Range: -55 to 75°C (-67 to 167°F)
- Conformal Coated PCBs for Dust & Humidity Protection
- Password Protection
- CSA Certified for Explosion-Proof / Dust-Ignition Proof / Flame-Proof
- ATEX and IECEx Certified as Intrinsically Safe and Explosion-Proof
- Flange for Wall or Pipe Mounting; Loop for Stainless Steel Tag; Holes for Tamper-Proof Seal
- Explosion-Proof, IP68, NEMA 4X Die-Cast Aluminum & Stainless Steel Enclosures
- 3-Year Warranty

PRECISION DIGITAL CORPORATION

233 South Street • Hopkinton MA 01748 USA
Tel (800) 343-1001 • Fax (508) 655-8990

www.predig.com

**PRECISION
DIGITAL**

The Complete PD6900 Series

VantageView+

Plastic Enclosures - General Purpose



PD6907-GP-PL
4-20 mA Input
Feet & Inches Meter



PD6908-GP-PL
4-20 mA Input
Process Meter



PD6928-GP-PL
4-20 mA Input
Flow Rate/Totalizer



PD6938-GP-PL
Pulse Input
Flow Rate/Totalizer



Aluminum Enclosures - Hazardous Area Approved



PD6907-HA-AL
4-20 mA Input
Feet & Inches Meter



PD6908-HA-AL
4-20 mA Input
Process Meter



PD6928-HA-AL
4-20 mA Input
Flow Rate/Totalizer



PD6938-XX-AL
Pulse Input
Flow Rate/Totalizer

Stainless Steel Enclosures - Hazardous Area Approved



PD6907-HA-SS
4-20 mA Input
Feet & Inches Meter



PD6908-HA-SS
4-20 mA Input
Process Meter



PD6928-HA-SS
4-20 mA Input
Flow Rate/Totalizer



PD6938-XX-SS
Pulse Input
Flow Rate/Totalizer

Table of Contents

- Introduction**6
- Key Features**7
- Ordering Information**11
 - Accessories**11
- Specifications**.....13
 - Display**13
 - General**13
 - Enclosure**14
 - Input**.....14
 - Common Open Collector & Relay Specifications**.....15
 - Open Collector Outputs**15
 - Solid-State Relays**15
 - 4-20 mA Transmitter Output**.....15
 - On-Board Digital Input**15
 - MeterView XL Software**.....16
- Compliance Information**.....17
 - Electromagnetic Compatibility**.....17
 - Hazardous Area Approvals**.....17
- EU Declaration of Conformity**.....18
- Safety Information**18
- Installation**.....18
 - Unpacking**18
- Mounting**.....19
 - Dimensions**19
 - Cover Jam Screw**.....19
- Connections**20
 - Display & Options Modules**20
 - Connectors Labeling**.....21
- Wiring Diagrams**23
 - Intrinsically Safe Wiring**.....23
 - I/O Parameter Table.....23
 - Explosion-Proof Wiring**.....23
 - Current Loop (4-20 mA) Connections23
 - Digital Input Connections24
 - 4-20 mA Output Connections24
 - Solid-State Relay Connections.....24
 - Open Collector Output Connections.....24
- Setup and Programming**25
 - Overview**.....25
 - CapTouch Buttons**25
 - CapTouch Buttons Delay25
 - Turning Off CapTouch Buttons.....25
 - CapTouch Button Tips & Troubleshooting25
 - MeterView XL Programming Software**.....26
 - CapTouch Buttons and Status Indicators**.....27
 - Display Functions & Messages**.....28
 - Main Menu**31
 - Setting Numeric Values.....32
 - Scaling the 4-20 mA Input (INPUT)**33
 - Available Unit Classes and Units34
 - Setting Custom Units (CUSTOM).....35
 - Scaling Example.....35
 - Setting the Display Features (DISPLAY)**36
 - Changing the Engineering Units (UNITS)36
 - Changing the Decimal Point (DECP)36
 - Enabling or Disabling Commas on the Bottom Display (COMMA)37
 - Display Capabilities Optimization (BOTTOM)37
 - Configuring the Display (BOTTOM)37
 - Programming the Bargraph (BARGRAPH).....38

Programming the Outputs (OUTPUT)38
 Open Collector Outputs (OPEN COLLECTR)39
 Solid-State Relay Outputs (RELAY)44
 Isolated 4-20 mA Output (4-20 mA)50
 Output Manual Control (CONTROL)50
Advanced Features Menu (ADVANCE).....51
 Advanced Process Variable Setup (ADV PV)52
 Low-Height Cutoff (CUTOFF)57
 Noise Filter (FILTER)57
 Enabling Password Protection (PASSWORD)57
 Programmable Function Keys User Menu (USER)58
 Tare (TARE).....59
 Changing System Settings (SYSTEM)60
Meter Operation62
CapTouch Buttons Operation62
CapTouch Buttons62
 CapTouch Button Tips & Troubleshooting62
Function Keys Operation.....63
Digital Input Operation.....63
Maximum/Minimum Readings63
Runtime & Cycle Count (INFO).....63
Changing PV2 Engineering Units63
Troubleshooting.....64
Reset Meter to Factory Defaults.....64
Determining Software Version64
 Factory Default Settings65
Troubleshooting Tips.....66

Table of Figures

Figure 1. Enclosure Dimensions – Front View 19
 Figure 2. Enclosure Dimensions – Side View 19
 Figure 3. Enclosure Dimensions – Top View 19
 Figure 4. Connector Labeling for PD6907-HA-##-LNN 21
 Figure 5. Connector Labeling for PD6907-HA-##-L2N 21
 Figure 6. Connector Labeling for PD6907-HA-##-L3N 22
 Figure 7. Connector Labeling for PD6907-HA-##-L5N 22
 Figure 8. 4-20 mA Input Connection without Backlight 23
 Figure 9. 4-20 mA Input Connection with Backlight 23
 Figure 10. Digital Input Connections 24
 Figure 11. 4-20 mA Output Connections 24
 Figure 12. Solid-State Relay Connections 24
 Figure 13. Open Collector Output Connections 24



Watch the Loop-Powered Meters Video



Click or Scan

Disclaimer

The information contained in this document is subject to change without notice. Precision Digital Corporation makes no representations or warranties with respect to the contents hereof; and specifically disclaims any implied warranties of merchantability or fitness for a particular purpose.

CAUTION

- Read complete instructions prior to installation and operation of the meter.

WARNINGS

- This product is not recommended for life support applications or applications where malfunctioning could result in personal injury or property loss. Anyone using this product for such applications does so at his/her own risk. Precision Digital Corporation shall not be held liable for damages resulting from such improper use.
- Failure to follow installation guidelines could result in death or serious injury. Make sure only qualified personnel perform the installation.
- For Explosion-Proof / Dust-Ignition Proof / Flame-Proof applications, never remove the meter cover in explosive environments when the circuit is live.
- Cover must be fully engaged to meet for Explosion-Proof / Dust-Ignition Proof / Flame-Proof requirements.

WARNING

Cancer and Reproductive Harm - www.P65Warnings.ca.gov

Limited Warranty

Precision Digital Corporation warrants this product against defects in material or workmanship for the specified period under "Specifications" from the date of shipment from the factory. Precision Digital's liability under this limited warranty shall not exceed the purchase value, repair, or replacement of the defective unit. See Warranty Information and Terms & Conditions on www.prediq.com for complete details.

Registered Trademarks

All trademarks mentioned in this document are the property of their respective owners.

© 2023 Precision Digital Corporation.
All rights reserved.

Introduction

The PD6907 ProtEX+ loop-powered explosion-proof & intrinsically safe feet and inches meters can be installed virtually anywhere to provide convenient and informative display of any 4-20 mA signal. They can operate down to -40°C and be installed in areas that get as cold as -55°C, however the display will cease functioning. One of the most convenient features of these instruments is their dual-line display. The top display is used to display level in feet and inches while the 8-character alphanumeric bottom display can be used to display a tag or custom message. Another common setup is to display the input in feet and inches on the top display and in another scale on the bottom display (such as the volume in gallons). The bottom display line uses 14-segment alphanumeric characters that provide much clearer indication of tags, units, or alarm messages than 7-segment characters do.

Further enhancing the display on these instruments is a 20-segment bargraph that also includes a numeric value of the percentage the bargraph represents.


These loop-powered meters can be installed virtually anywhere because they get their power from the 4-20 mA loop and therefore require no separate power source. And they only drop 1.5 V (4.7 V with backlight), so they add very little burden to the loop. Additional features that allow these instruments to be installed virtually anywhere include a NEMA 4X, IP68 explosion-proof enclosure, an operating temperature range of -40 to 167°F (-40 to 75°C), conformally coated PCBs, and a backlit LCD that can be read in bright sunlight or dimly lit areas.

The ProtEX+ Series is CSA Certified as Explosion-Proof / Dust-Ignition Proof / Flame-Proof and ATEX and IECEx Certified as Intrinsically Safe and Explosion-Proof. The enclosure itself is ATEX, IECEx, CSA, and UL approved.

Free, PC-based, MeterView XL software that connects to the meter via a micro USB cable is available for programming and setup of the meters. For more details, see the [MeterView XL manual](#). Four CapTouch through-glass buttons are available to operate the instrument without removing the cover.


All models come equipped with two open collector outputs and a digital input. There are also models available with two solid-state relays and isolated 4-20 mA analog output options. The open collector outputs are useful for alarm indication. The digital input can be used to acknowledge the relays, to start/stop a timer/stopwatch, and more. The relays can be programmed for alarm indication, on/off control, or pump alternation.

Key Features



2X More Informative Display

The PD6907 display offers a 50% larger display area and is twice more informative than previous generations of loop-powered explosion-proof meters. Featuring an alphanumeric dual-line display and a 20-segment bargraph, reading and understanding process values is easy and intuitive. The addition of status indicators provides a quick glance at alarm conditions, relays, process trends, and more. Predefined display units give users even more display flexibility. Plus, the high contrast backlit LCD display is readable from far away and under various lighting conditions.



Backlight Turns Red on Alarm

When an alarm occurs, the display can be programmed to turn red, flash, and display an alarm indicator . In addition, a unique custom alarm message for each of the two relays and two open collectors can be displayed on the bottom display. These features can be activated even if no relay or open collector is connected.

CapTouch Through-Glass Buttons


The PD6907 is equipped with four capacitive sensors that operate as through-glass buttons so that it can be operated without removing the cover (and exposing the electronics) in a hazardous area. CapTouch buttons are designed to work under any lighting condition and to protect against false triggering. They can be disabled for security via a switch on the display module.



CapTouch buttons have two modes of operation: Normal and Delayed. Delayed mode prevents accidental trigger of the buttons. In the Delayed mode, the buttons enter into a low sensitivity state (sleep) and they ignore quick button presses after 20 seconds of inactivity. To wake up the buttons, press and hold any button for more than 2 seconds, the buttons respond normally.

Feet & Inches Display with Bargraph

Designed for users that prefer to read level in feet and inches instead of a decimal format, the PD6907 can display level up to 999FT 11IN & 15/16 on the top display. The bottom display can toggle between a tag (Tank 4) and units (Gallons), and if dual-scale mode is enabled, then the input can be displayed in a different scale such as volume (17,500).



Predefined and Custom Units

The meter has six available preprogrammed unit classes when programming PV2: volume, height, temperature, pressure, weight, and rate. When the desired unit class or unit of measure within a class is not available, a custom unit may be programmed.

14-Segment Characters

Notice how much better letters like “T”, “N” and “K” appear as 14-segment characters on the bottom display vs. 7-segment characters found on other meters.



Password Protection

A password can be set up for programming security to prevent unauthorized changes to the programmed parameter settings.

Enable / Disable Backlight

The backlight may be enabled or disabled using the System - Backlight menu. The backlight is enabled by default, but the input must be wired appropriately for the backlight to function. See *Enabling or Disabling the Backlight (BACKLITE)* on page 61 for details.

Multiple Outputs

- Two open collector outputs (standard)
- Two solid-state relays (optional)
- One 4-20 mA output (optional)

The open collector outputs and relays generally operate in the same manner, with the major exception being the open collectors are not available for pump alternation and the relays are not available with pulse features. The open collectors and relays can be controlled either automatically or manually.

The isolated analog output signal can be configured to represent the process variable (PV1, PV2, or retransmit). It can also be reverse scaled such that the meter’s high calibration value outputs 4 mA and the meter’s low calibration outputs 20 mA.



Free MeterView XL Programming Software

The fastest and easiest way to program the meter is using the free MeterView XL programming software. This software greatly simplifies the programming process and allows the user to save configuration files for later use.

The meter connects to the PC via a provided micro-USB cable and is powered by the USB connection, so no additional power is needed during programming.



Wide Viewing Angle

The window and display module have been optimized to provide a wide viewing angle of approximately ±40°; nearly twice that of the competition. Plus, the display module can be rotated in 90° increments providing added mounting flexibility.

Modern and Practical Enclosure

The PD6907 NEMA 4X, IP68 enclosure provides serious protection from the elements, high impact, corrosion, and electrical interference. Plus, the extensive worldwide agency approvals allow it to be installed virtually anywhere.



Aluminum or Stainless Steel Enclosure

The enclosure is available in copper-free (0.3%), die-cast aluminum and type 316 stainless steel.




Built-In Flange for Pipe Mounting

The built-in mounting flange allows easy mounting to walls or pipes.



A slot on the back makes it easy to center the unit on a pipe. There are two 3/4" NPT threaded conduit holes for wiring.



Grounding Screw

A grounding screw is provided on the top of the enclosure.



SS Tag Attaching Loop

The enclosure is also equipped with a loop at the top to easily attach a PDA-SSTAG stainless steel tag.




Tamper-Proof Capability

The instrument can be made tamper-proof by inserting a wire through the built-in loop on the base of the enclosure and a hole in the lid of the enclosure and securing this wire with a lead seal.


Pump Alternation

The PD6907 can be used as a pump controller to alternate two pumps and indicate high and low alarm conditions. The pumps can be programmed to alternate on level and runtime and the display can be programmed to turn red and flash a message on alarm conditions. The meter can display the pump runtimes and the number of times they have cycled.

See the *Pump Control with Alternation & Alarm Example* on page 48 for full details.



Relay #2 turns the main pump on at 30 feet and turns it off at 10 feet. **R2** lights up to show relay 2 is energized. The **▲** indicates level is rising.



With the Pump Alternation feature activated, the next time the level reaches 30 feet, relay #1 transfers and starts the backup pump. **R1** lights up to show relay 1 is energized.



Easy Wiring & Service

The PD6907 has been designed for easy wiring and servicing. All connections are made to removable screw terminal blocks. There are no exposed printed circuit boards.

Input Signal Conditioning

The *Function* menu is used to select the input signal conditioner applied to the input: linear or round horizontal tank volume calculation. Multi-point linearization is part of the linear function selection.


Meters are set up at the factory for linear function with 2-point linearization. The linear function provides a display that is linear with respect to the input signal.

Multi-Point Linearization

Up to 32 linearization points can be selected for PV1 and PV2 under the linear function. Multi-point linearization can be used to linearize the input so the meter can display volume from non-linear tanks or to convert level to flow using weirs and flumes with complex equations to convert level to flow using weirs and flumes with complex equations.

If the dual-scale level feature has been selected, the menus for PV1 & PV2 are enabled.

Round Horizontal Tank Linearization



This function automatically calculates the volume in a round horizontal tank with flat ends and allows that reading to be displayed on the bottom display. This results in a meter that displays the height of the tank in convenient to read feet and inches on the top display and volume on the lower display. The user only needs to enter the diameter and length of the tank and the meter takes care of the rest.

Ordering Information

Hazardous Area Instruments

| ProtEX+ PD6907 • Feet & Inches – Aluminum Enclosure | |
|---|---|
| Model | Description |
| PD6907-HA-AL-LNN | Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, No Options |
| PD6907-HA-AL-L2N | Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, Two Solid-State Relays |
| PD6907-HA-AL-L3N | Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, 4-20 mA Analog Output |
| PD6907-HA-AL-L5N | Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, Two Solid-State Relays & 4-20 mA Analog Output |

| ProtEX+ PD6907 • Feet & Inches – Stainless Steel Enclosure | |
|--|---|
| Model | Description |
| PD6907-HA-SS-LNN | Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, No Options |
| PD6907-HA-SS-L2N | Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, Two Solid-State Relays |
| PD6907-HA-SS-L3N | Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, 4-20 mA Analog Output |
| PD6907-HA-SS-L5N | Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, Two Solid-State Relays & 4-20 mA Analog Output |

Notes:

- All models come with bargraph, two open collector outputs, and one digital input standard.
- The meter comes standard with two 3/4" NPT conduit holes. To order models with M20 conduit holes instead, add -21 at the end of the part number (e.g. PD6907-HA-AL-LNN-21)

Accessories

| Model | Description |
|-------------------------------------|---|
| PD659 | Signal Isolators, Splitters, and Conditioners |
| PD9501 | Multi-Function Calibrator |
| PD9502 | Low-Cost Signal Generator |
| PDA1002 | 6" DIN Rail Mounting Kit |
| PDA1024-01 | 24 VDC Transmitter Power Supply for DIN Rail |
| PDA6846 | Steel 2" U-Bolt Kit. All Material: Zinc Plated Steel; (1) U-Bolt for 2" Pipe with (2) Washers, (2) Lock Washers, and (2) Nuts |
| PDA6846-SS | Stainless Steel 2" U-Bolt Kit. All Material: Stainless Steel; (1) U-Bolt for 2" Pipe with (2) Washers, (2) Lock Washers, and (2) Nuts |
| PDAPLUG75 | 3/4" NPT 316 Stainless Steel Conduit Plug with Approvals |
| PDAREDUCER-75M-50F | M-3/4" NPT to F-1/2" NPT Reducer with Approvals |
| PDAREDUCER-75M-M20F | M-3/4" NPT to F-M20 Reducer with Approvals |
| PDA-SSTAG | Custom Stainless Steel Tag (see website for convenient ordering form) |

WARNING

- Accessories do not carry hazardous area approvals unless otherwise specified and are thus not suitable for location in hazardous areas. The use of additional protective devices may allow them to be installed in a safe area and connected to a device in a hazardous area. User should consult a professional engineer to determine suitability of these products for their specific application.

PDA1024-01 24 VDC Power Supply



The PDA1024-01 is a DIN rail mounted 1.5 A, 24 VDC power supply that can be used to power the 4-20 mA transmitter.

PDA6846 2" U-Bolt Kits



The PDA6846 U-Bolt Kits provide a convenient way to mount the meter to 1.5" or 2" pipes. They are available in steel and stainless steel.

PDA-SSTAG Stainless Steel Tag



The PDA-SSTAG is a laser etched stainless steel tag that can be customized with three lines of text. Each tag comes with a stainless steel wire and lead seal for easy mounting wherever you need.

PD9501 Multi-Function Calibrator



This [PD9501](#) Multi-Function Calibrator has a variety of signal measurement and output functions, including voltage, current, thermocouple, and RTD.

PD9502 Low-Cost Signal Generator



The [PD9502](#) is a low-cost, compact, simple to use 4-20 mA or 0-10 VDC signal generator. It can easily be set for 0-20 mA, 4-20 mA, 0-10 V or 2-10 V ranges. Signal adjustment is made with a one-turn knob. A wall plug is provided with the instrument. Optional USB power bank is available.

Specifications

Except where noted all specifications apply to operation at +25°C.

Display

| | |
|------------------------------|--|
| Display | Dual-line LCD with backlight. Top: 0.7" (17.8 mm) 5 digits 7-segment, FT-IN & fractions Bottom: 0.4" (10.2 mm), 8 alphanumeric 14-segment characters Display may be programmed to turn red and flash a user-defined message on alarm condition. |
| On-Screen Indicators | See <i>CapTouch Buttons and Status Indicators</i> on page 27 for details. |
| Top Display | -99FT 11IN 15/16 to 999FT 11IN 15/16 |
| Bottom Display | 8 digits (-9,999,999 to 99,999,999; separated by commas) or 8 characters (all capital & most lower-case letters) |
| Backlight | Powered by 4-20 mA loop Intensity varies with signal level |
| Bargraph | 20 segments, numeric percent indication at the top of the bargraph |
| Decimal Point | Up to seven decimal places on bottom display |
| Commas | Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only |
| Dual-Scale Feature | The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units. |
| Alarm Indication | Programmable: loop-powered red backlight, flashing display, alarm symbol ▲, bargraph segment flashes on alarm. |
| Custom Alarm Messages | Programmable for each relay/open collector: 8 characters maximum; displayed every 10 sec for 1 sec on bottom display. May be turned off. |
| Display Update Rate | Ambient > -10°C: 1 Update/Second Ambient = -20°C: 1 Update/2 Seconds From -20°C to -40°C the update rate slows down 1 second for every -2°C (e.g. at -24°C, 1 update/4 seconds). |
| Overrange | Top: 999 11 15/16; Bottom: 99,999,999 (flashing) |
| Underrange | Top: -99 11 15/16; Bottom: -9,999,999 (flashing) |

General

| | |
|------------------------------|--|
| Programming Method | Four CapTouch through-glass buttons when cover is installed. The CapTouch buttons can be used with the cover removed. Free PC-based USB MeterView XL programming software. |
| Environmental | Operating temperature range: -40 to 75°C (-40 to 167°F) Storage temperature range: -55 to 85°C (-67 to 185°F) Installation temperature range: -55 to 75°C (-67 to 167°F) (The display ceases to function, however inputs and outputs continue to operate) Relative humidity: 0 to 90% non-condensing Printed circuit boards are conformally coated |
| Noise Filter | Averages the input signal over a period of time between 1 and 16 seconds to dampen the effects of a noisy signal that causes a jumpy display. |
| Filter Bypass | 0.0 to 99.9% of full scale. Input signal changes that are greater than the bypass value are displayed immediately. |
| Recalibration | Recalibration is recommended at least every 12 months. |
| Max / Min Display | Max / min readings reached by the process are stored until reset by the user or until power to the meter is turned off. |
| Tare | Tare function zeros out the meter to remove the weight of a container. Tare function can be assigned to a function key or the digital input. |
| Password | Programmable password restricts modification of programmed settings. |
| Non-Volatile Memory | All programmed settings are stored in non-volatile memory for a minimum of ten years if power is lost. |
| Normal Mode Rejection | 64 dB at 50/60 Hz |
| Connections | Removable screw terminal blocks Display terminals: accept 16 to 30 AWG wire Relay terminals: accept 12 to 26 AWG wire 4-20 mA output: accept 16 to 30 AWG wire |
| Tightening Torque | Display terminals: 2.5 lb-in (0.28 Nm) Relay terminals: 4.5 lb-in (0.5 Nm) 4-20 mA output terminals: 2.5 lb-in (0.28 Nm) |
| Overall Dimensions | 5.25" x 5.65" x 4.80" (133 x 144 x 122 mm) (W x H x D) |
| Weight | Aluminum: 5.1 lbs (2.3 kg) Stainless Steel: 9.4 lbs (4.3 kg) |
| Warranty | 3 years parts and labor. See Warranty Information and Terms & Conditions on www.prediq.com for complete details. |

Enclosure

| | |
|--|--|
| Material | -AL Models: ASTM A413 LM6 die-cast aluminum, copper-free, enamel coated. -SS Models: ASTM A743 CF8M investment-cast 316 stainless steel |
| Gasket | Fluoroelastomer |
| Rating | NEMA 4X, IP68 Explosion-proof |
| Color | -AL: Blue; -SS: Silver |
| Window | Borosilicate glass |
| Conduits | Two ¾" NPT threaded conduit openings. M20 conduits are available. See <i>Ordering Information</i> on page 11 for details. |
| Conduit Stopping Plug | Sold separately. See <i>Ordering Information</i> on page 11 for details. |
| Flange | Built-in flange for wall and pipe mounting. |
| Tamper-Proof Seal | Enclosure lid may be secured with tamper-proof seal. |
| Instrument Tag Loop | Built-in loop for securing stainless steel tag |
| Overall Dimensions | 5.25" x 5.65" x 4.80" (133 x 144 x 122 mm) (W x H x D) |
| Weight | Aluminum: 4.8 lbs (2.18 kg) Stainless Steel: 9.0 lbs (4.08 kg) |
| ATEX & IECEx (Enclosure only) | Flameproof protection Ⓢ II 2GD Ex db IIC Gb Ex tb IIIC Db IP66/IP68 Tamb: -55°C to +85°C Certificate No.: Sira 19ATEX1252U Certificate No.: IECEx SIR 19.0075U |
| CSA (Enclosure only) | Class I, Division 1, Groups A, B, C, D Class II, Division 1, Group E, F, G; Class III Ex db IIC Gb Ex tb IIIC Db Class I, Zone 1, AEx db IIC Gb; Zone 21, AEx tb IIIC Db IP66/IP68/TYP E 4X Tamb: -55°C to +85°C Certificate No.: 80011200 |
| UL (Enclosure only) | Class I, Division 1, Groups A, B, C and D Class II, Division 1, Groups E, F and G Class III; Class I, Zone 1, AEx db IIC Gb Zone 21, AEx tb IIIC Ex db IIC Gb Ex tb IIIC Db IP66/IP68/TYP E 4X Tamb: -55°C to +85°C Certificate Number: E518920 |

Note: The above approvals are for the enclosure only. See *Hazardous Area Approvals* on page 17 for approvals on the entire instrument.

Input

| | |
|------------------------------|---|
| Input | 4-20 mA |
| Accuracy | ±0.02% of span ±1 count, Square root and programmable exponent: 10-100% FS |
| Voltage Drop | Without backlight: 1.5 V maximum, With backlight: 4.7 V maximum |
| Equivalent Resistance | Without backlight: 75 Ω @ 20 mA With backlight: 235 Ω @ 20 mA |
| Input Overload | Over current protection to 1 A maximum, Over voltage protection to 30 VDC max (Between mA+ and mA- / BL-) |
| Temperature Drift | 25 PPM/°C from -40 to 75°C ambient |
| Function | PV1: Linear (2-32 points), square root, or programmable exponent PV2: Linear (2-32 points) or round horizontal tank |
| Low-Height Cutoff | 1/16 to 999 FT 11IN 15/16 or disable. Point below at which the display always shows zero. |
| HART Transparency | The meter does not interfere with existing HART communications; it displays the 4-20 mA primary variable and it allows the HART communications to pass through without interruption. The meter is not affected if a HART communicator is connected to the loop. The meter does not display secondary HART variables. |

Common Open Collector & Relay Specifications

| | |
|--------------------------------|--|
| Number | Two open collectors & two relays |
| High or Low Alarm | User programmable for high or low alarm |
| Alarm Deadband | 0-100% FS, user programmable |
| Output Assignment | Alarm, Timer, Stopwatch, or Disable |
| Alarm Output Source | Assign to PV (PV1, PV2) or Digital Input |
| On & Off Time Delay | 0 to 9,999 seconds |
| Fail-Safe Operation | Independent for each open collector and relay. Fail-safe on, the output is on under normal conditions. Fail-safe off, the output is on under alarm conditions. |
| Alarm Operation | Automatic, automatic with manual override, latching (manual reset anytime), latching with reset after cleared (manual reset only after alarm has cleared) |
| Alarm Indication | Programmable: loop-powered red backlight, flashing display, alarm symbol ▲, bargraph segment flashes on alarm. |
| Custom Alarm Messages | Programmable for each relay/open collector: 8 characters maximum; displayed every 10 sec for 1 sec on bottom display. May be turned off. |
| Alarm Acknowledge | CapTouch ACK button or external digital input resets output and screen indication. |
| Auto Initialization | When power is applied to the meter, open collectors and relays will reflect the state of the input to the meter. |
| Timer Output | One-shot or Continuous Off Time Delay: 1 sec to 99:59:59 (hrs:min:sec) On Time: 1 sec to 99:59:59 (hrs:min:sec) |
| Stopwatch | Output turns on when started and off when stopped. |

Open Collector Outputs

| | |
|--------------------------------|---|
| Rating | Isolated open collector, sinking NPN 5-30 VDC @ 150 mA maximum |
| Output Assignment | Pulse, Alarm, Timer, Stopwatch, or Disable |
| Pulse Output Source | PV (PV1, PV2) or Test Frequency |
| Pulse Output Factor | 0.000001 to 999,999.9 |
| Pulse Width | 0.5 ms @ 1 kHz; 500 ms @ 1 Hz; 50% duty cycle |
| Pulse Output Frequency | 1,000 Hz maximum |
| Quadrature Pulse Output | Available for Output 2 (90° behind Output 1) 500 Hz max |
| Alarm Output Source | Assign to PV (PV1, PV2) or Digital Input |

Solid-State Relays

| | |
|-----------------------------|--|
| Rating | 250 VAC/VDC @ 0.5 A resistive 38 VA; 250 VAC; 0.3 A pilot duty (inductive) 13 VA; 250 VDC; 0.3 A pilot duty (inductive) |
| Noise Suppression | Metal oxide varistors across outputs |
| Relay Assignment | Pump Alternation, Alarm, Timer, Stopwatch on/off, or Disable |
| Alarm Output Source | Assign to PV (PV1, PV2) or Digital Input |
| Pump Alternation | Relays may be programmed to alternate with each pump cycle with an elapsed time override where the pumps will alternate regardless of level. Pump alternation time can be programmed for 0 to 999:59 (hrs:min) |
| Relay (Pump) Runtime | Meter will keep track of how long each relay (pump) has operated and display this information. |
| Relay (Pump) Cycles | Meter will keep track of how many times the relays (pumps) have cycled and display this information. |

4-20 mA Transmitter Output

| | |
|-----------------------------------|---|
| Accuracy | ±0.05% FS ±0.001mA |
| Output Source | PV1, PV2, re-transmit; reverse scaling allowed |
| Scaling Range | 1.00 to 23.0 mA |
| Disable | High impedance state, less than 1 mA |
| Calibration | Factory calibrated 4.00 to 20.00 mA |
| Underrange | 1.0 mA, 3.5 mA, or 3.8 mA (If input < 3.5 mA); or Off; user selectable |
| Overrange | 20.5 mA, 20.8 mA, or 23.0 mA (If input > 20.5 mA); or Off; user selectable |
| Isolation | 500 V input-to-output |
| Temperature Drift | 0.5 µA/°C max from -40 to 75°C ambient |
| External Loop Power Supply | 7.0 VDC to 30.0 VDC maximum |
| Output Loop Resistance | 10-750 Ω @ 24 VDC; 10-1100 Ω @ 30 VDC |

On-Board Digital Input

| | |
|---------------------|---|
| Function | Remote acknowledge/reset relays, reset max/min values, etc. See User section of <i>Display Functions & Messages</i> on page 28 for a complete list of capabilities. |
| Contacts | 2.1 VDC on contact. Connect normally open contacts across DI+ and DI- |
| Logic Levels | Logic High: 2.4 to 30 VDC (max) Logic Low: 0 to 0.9 VDC |

MeterView XL Software

| | |
|-----------------------------|--|
| Availability | Free download from www.prediq.com |
| System Requirements | Microsoft® Windows® 7 & 10 |
| Communications | USB 2.0 (Standard USB A to Micro USB B) Cable provided |
| Configuration | Configure all parameters on the meter. Configure meters one at a time. |
| Configuration Files | Generate with or without meter connected; Save to file for later use. |
| USB Power Connection | Meter is powered by USB connection during programming, if 4-20 mA loop is not connected. |

WARNING

- The meter should only be connected to a computer while it is located in a safe area

| | |
|----------------------|--|
| Compatibility | Programs created for Loop Leader and Loop Leader+ may be run on either meter. Programs created for VantageView+ and ProtEX+ can be run on either meter. No other program sharing is permissible. |
|----------------------|--|



To download the latest MeterView XL programming software and manual, visit prediq.com/meterviewxl.

Compliance Information

Electromagnetic Compatibility

| | |
|-----------------------------------|---|
| EMC Emissions | <ul style="list-style-type: none"> CFR 47 FCC Part 15 Subpart B Class A emissions requirements (USA) ICES-003 Information Technology emissions requirements (Canada) AS/NZS CISPR 11 Group 1 Class A ISM emissions requirements (Australia/New Zealand) EN 55011 Group 1 Class A ISM emissions requirements (EU) EN 61000-6-4 Emissions requirements for Heavy Industrial Environments - Generic |
| EMC Emissions and Immunity | EN 61326-1 EMC requirements for Electrical equipment for measurement, control, and laboratory use – industrial use |

Hazardous Area Approvals

| | |
|--------------|--|
| CSA | <p>Explosion-proof for use in: Class I, Division 1, Groups B, C and D</p> <p>Dust-ignition proof for use in: Class II/III, Division 1, Groups E, F and G; T6</p> <p>Flame-proof for use in: Zone 1, Ex d IIC T6 Ta = -55 to 75°C.</p> <p>Enclosure: Type 4X & IP66/IP68. Certificate number: 2325749</p> |
| ATEX | <p>Intrinsically safe for use in:</p> <p>⊕ II 1 G D Ex ia IIC T4 Ga Ex ia IIIC T200°C Da Ta = -55 to 75°C Enclosure: Type 4X & IP66/IP68 Install per Control Drawing DW2636 (contained within LIM6908-2) Certificate number: CML 18ATEX2089X</p> <p>Explosion-proof for use in:</p> <p>⊕ II 2 G D Ex db IIC T6 Gb Ex tb IIIC T85°C Db IP68 Ta = -55 to 75°C Certificate number: Sira 10ATEX1116X</p> |
| IECEX | <p>Intrinsically safe for use in:</p> <p>Ex ia IIC T4 Ga Ex ia IIIC T200°C Da Ta = -55 to 75°C Enclosure: Type 4X & IP66/IP68 Install per Control Drawing DW2636 (contained within LIM6908-2) Certificate number: IECEX CML 18.0050X</p> <p>Explosion-proof for use in:</p> <p>Ex db IIC T6 Gb Ex tb IIIC T85°C Db IP68 Ta = -55 to 75°C Certificate number: IECEX SIR 10.0056X</p> |

ATEX/IECEX Special Conditions for Safe Use

The following conditions relate to safe installation and/or use of the equipment.

- The equipment loop/power port shall be connected to an intrinsically safe barrier with $U_o \geq 5.8V$
- The 4-20 mA input port shall be connected to an intrinsically safe barrier with $U_o \geq 5.1V$
- The PD6907-HA-AL enclosure is manufactured from aluminum. In rare cases, ignition sources due to impact and friction sparks could occur. This shall be considered during installation, particularly if the equipment is installed in a Zone 0 location.
- All cable entries into the equipment shall be via cable glands or conduit which provide a minimum degree of protection of IP54.
- The equipment may not have 500V isolation between the circuit and earth. This shall be taken into account when installing the equipment.
- The equipment label and epoxy coating may generate an ignition-capable level of electrostatic charges under certain extreme conditions. The user should ensure that the equipment is not installed in a location where it may be subjected to external conditions (such as high-pressure steam) which might cause a buildup of electrostatic charges on non-conducting surfaces. Additionally, cleaning of the equipment should be done only with a damp cloth.
- Flameproof joints are not intended to be repaired.
- All entry closure devices shall be suitably certified as "Ex d", "Ex t" and "IP66/68" as applicable. Suitable thread sealing compound (non-setting, non-insulating, non-corrosive, not solvent based, suitable for the ambient rating) must be used at the NPT conduit entries to achieve the IPx8 rating while maintaining the Ex protection concept.

Year of Construction

This information is contained within the serial number with the first four digits representing the year and month in the YYMM format.

For European Community:

The PD69XX Series must be installed in accordance with the ATEX directive 2014/34/EU, the product certificates CML 18ATEX2089X, Sira 10ATEX1116X, IECEX CML 18.0050X, IECEX SIR 10.0056X and the product manual.

EU Declaration of Conformity

For shipments to the EU and UK, a Declaration of Conformity was printed and included with the product. For reference, a Declaration of Conformity is also available on our website www.prediq.com/docs.

Safety Information

⚠ CAUTION

- Read complete instructions prior to installation and operation of the meter.

⚠ WARNINGS

- Hazardous voltages exist within enclosure. Installation and service should be performed only by trained service personnel.
- Service requiring replacement of internal components must be performed at the factory.
- Control room equipment must not use or generate more than 250 VRMS or VDC.
- Hazardous location installation instructions for associated apparatus (barrier) must be followed when installing this equipment.
- For safe installation of an ATEX approved transmitter in series with PD6907 loop-powered feet & inches meters, the hazardous location installation instructions for the transmitter, PD6907 loop-powered feet & inches meter, and associated apparatus (barrier) must be compatible.
- PD6907 loop-powered feet & inches meters do not add capacitance or inductance to the loop under normal or fault conditions.
- Substitution of components may impair hazardous location safety.
- Equipment contains non-metallic materials and therefore special care and consideration should be made to the performance of these materials with respect to chemicals which may be present in a hazardous environment.

Installation

To access the connectors, remove the enclosure cover and unclip the display module by pulling it from the enclosure. The display module may be disconnected from the options module to facilitate wiring to the options module.

Refer to Control Drawing (DW2636 - Contained within the [LIM6908-2](#)) for details related to intrinsically safe field wiring.

⚠ WARNING

Explosion-Proof / Dust-Ignition Proof / Flame-Proof

- Disconnect from supply before opening enclosure. Keep cover tight while circuits are live. Conduit seals must be installed within 18" (450mm) of the enclosure.

Unpacking

Remove the meter from box. Inspect the packaging and contents for damage. Report damages, if any, to the carrier.

If any part is missing or the meter malfunctions, please contact your supplier or the factory for assistance.

Mounting

The PD6907 has a slotted mounting flange that may be used for pipe mounting or wall mounting. Alternatively, the unit may be supported by the conduit using the conduit holes provided. Refer to *Figure 1* and *Figure 2*.

- ⚠ WARNING**
- Do not attempt to loosen or remove flange bolts while the meter is in service.

Dimensions




Figure 1. Enclosure Dimensions – Front View




Figure 2. Enclosure Dimensions – Side View




Figure 3. Enclosure Dimensions – Top View

ENCLOSURE
CAD
DIMENSIONAL DRAWINGS

Download free 3-D CAD files of these instruments to simplify your drawings!

predig.com/documentation-cad

Cover Jam Screw

The cover jam screw should be properly installed once the meter has been wired and tested in a safe environment. The cover jam screw is intended to prevent the removal of the meter cover in a flame-proof environment without the use of tools. Using a M2 hex wrench, turn the screw clockwise until the screw contacts the enclosure's base. Turn the screw an additional 1/4 to 1/2 turn to secure the cover.



- ⚠ CAUTION**
- Excess torque may damage the threads, screw head, and/or wrench.

Connections

To access the connectors, remove the enclosure cover and unclip the display module by pulling it from the enclosure. Signal, backlight, open collector, and digital input connections are made to removable connectors on the display module. Relays and 4-20 mA output connections (if installed) are made to removable connectors on the options module mounted in the base of the enclosure. The display module may be disconnected from the options module to facilitate wiring to the options module. Grounding connections are made to the two ground screws provided on the base of the enclosure, one internal and one external.

⚠ WARNINGS

- Observe all safety regulations. Electrical wiring should be performed in accordance with all agency requirements and applicable national, state, and local codes to prevent damage to the meter and ensure personnel safety.
- Static electricity can damage sensitive components.
- Observe safe handling precautions for static-sensitive components.
- Use proper grounding procedures/codes.
- If the meter is installed in a high voltage environment and a fault or installation error occurs, high voltage may be present on any lead or terminal.

Display & Options Modules

The display module snaps into built-in rails on the enclosure ensuring a secure and perfect fit every time. No tools are needed to install or remove it. The options module is screwed into the base of the enclosure. Both modules completely encase the printed circuit boards.



Options Board (Left) and Display Module (Right)



Options Board Connected to Display Module



Options Board Mounted on the Bottom of Enclosure



Display Module Mounted on Built-In Rails

Connectors Labeling

The following graphics show the locations of the connectors for each available configuration.




Figure 4. Connector Labeling for PD6907-HA-##-LNN




Figure 5. Connector Labeling for PD6907-HA-##-L2N




Figure 6. Connector Labeling for PD6907-HA-##-L3N




Figure 7. Connector Labeling for PD6907-HA-##-L5N

Wiring Diagrams

Intrinsically Safe Wiring

⚠ WARNING

- PD6907 installation must be performed in accordance with control drawings included in the [LIM6908-2](#), in order to meet agency approval ratings.
- For ATEX certification, barrier and transmitter must be ATEX Certified with Entity Parameters and must be connected per manufacturer's instructions.
- Service requiring replacement of internal components must be performed at the factory.
- Entire meter assembly (electronic assembly) may be replaced in the field with a unit supplied from the factory labeled "Field Modification".

I/O Parameter Table

| 4-20 mA Loop Input | | | Switch Port | | |
|------------------------|---|----------|--------------------|---|--------|
| U _i | = | 30 V | U _i | = | 30 V |
| I _i | = | 175 mA | I _i | = | 175 mA |
| P _i | = | 1 W | P _i | = | 1 W |
| C _i | = | 0 | C _i | = | 0 |
| L _I | = | 0 | L _I | = | 0 |
| Open Collector Outputs | | | Backlight Terminal | | |
| U _i | = | 30 V | U _i | = | 30 V |
| I _i | = | 175 mA | I _i | = | 175 mA |
| P _i | = | 1 W | P _i | = | 1 W |
| C _i | = | 0 | C _i | = | 0 |
| L _I | = | 0 | L _I | = | 0 |
| Power Supply Input | | | mA Output | | |
| U _i | = | 30 V | U _i | = | 30 V |
| I _i | = | 175 mA | I _i | = | 175 mA |
| P _i | = | 1 W | P _i | = | 1 W |
| C _i | = | 0 | C _i | = | 0 |
| L _I | = | 0 | L _I | = | 0 |
| Relay Outputs | | | | | |
| U _i | = | 30 V | | | |
| I _i | = | 1000 mA | | | |
| P _i | = | 1 W | | | |
| C _i | = | 0.013 uF | | | |
| L _I | = | 0 | | | |
| U _o | = | 11.55 V | | | |
| I _o | = | 1 mA | | | |
| P _o | = | 0.012 W | | | |

Explosion-Proof Wiring

Current Loop (4-20 mA) Connections

Signal connections are made to a three-terminal connector. See *Connectors Labeling* on page 21. The following figures show a 4-20 mA current loop connected to the meter. *Figure 8* shows the connection without the backlight and *Figure 9* shows the connection with the backlight (the backlight can be disabled/enabled in the SYSTEM menu, if connected). The meter and the backlight are powered by the 4-20 mA current loop.

There are no switches or jumpers to set up for the input. Setup and programming are performed through the CapTouch buttons or PC-based software.




Figure 8. 4-20 mA Input Connection without Backlight




Figure 9. 4-20 mA Input Connection with Backlight

The current input is protected against current overload up to 1 amp. The display may or may not show a fault condition depending on the nature of the overload.

Digital Input Connections

A digital input is standard on the meter. This digital input is connected with a normally open contact across DI+ and DI-, or with an active low signal applied to DI+ and DI-.




Figure 10. Digital Input Connections

4-20 mA Output Connections

Connections for the 4-20 mA transmitter output are made to the connector terminals labeled 4-20 mA Output on Figure 6, on page 22. The 4-20 mA output must be powered from an external power supply.




Figure 11. 4-20 mA Output Connections

Solid-State Relay Connections

Relay connections are made to two-terminal connectors, as shown on Figure 5, page 21. Each relay's C terminal is common only to the normally open (NO) contact of the corresponding relay.




Figure 12. Solid-State Relay Connections

Open Collector Output Connections

Open collector output 1 and 2 connections are made to terminals labeled OC1 and OC2 on Figure 4, page 21. Connect the alarm or pulse input device as shown below.




Figure 13. Open Collector Output Connections

Setup and Programming

The meter is factory calibrated prior to shipment to display 0.00 to 100.00, which corresponds to the 4-20 mA input. The calibration equipment is traceable to NIST standards.

Overview

There are no jumpers to set; setup and programming is done through the CapTouch buttons or the free MeterView XL PC-based software.

The meter may be powered via the micro-USB connection located on the display module for the purpose of programming only. The backlight will not work while the meter is powered via the USB connection.

CapTouch Buttons

The PD6907 is equipped with four capacitive sensors that operate as through-glass buttons so that it can be programmed and operated without removing the cover (and exposing the electronics) in a hazardous area.



These buttons can be turned off for security by selecting the *Off* setting on the switch located on the side of the display module, close to the Menu button.

To actuate a button, press one finger to the window directly over the marked button area. When the cover is removed, the CapTouch buttons can be used after the meter completes a self-calibrating routine (hand symbol flashes). The sensors are disabled when more than one button is pressed, and they will automatically re-enable after a few seconds (hand symbol off).

CapTouch Buttons Delay

The CapTouch have two modes of operation: *Normal* and *Delayed*. Use the Delayed mode to prevent accidental trigger of the buttons. In the Delayed mode, the buttons enter into a low sensitivity state (sleep) and they ignore quick button presses after 20 seconds of inactivity. To wake up the buttons, press and hold any button for more than 2 seconds, the buttons respond normally.

Turning Off CapTouch Buttons

The CapTouch buttons can be turned off for security by moving the slide switch located on the display module to the *Off* position.



CapTouch Button Tips & Troubleshooting

The CapTouch buttons are designed to work under any lighting condition and to protect against false triggering. If the CapTouch buttons are not needed during operation, they can be turned off (slide switch to *Off*).

- To remove cover with power applied (safe area only), or to clean the window, place your hand over the buttons; this will temporarily disable the CapTouch buttons to prevent inadvertent use.
- Keep the glass window clean.
- Tighten the cover securely.
- Use a password to prevent tampering.

IMPORTANT

- CapTouch buttons will not work if two or more buttons are detected as being pressed simultaneously. Be careful to avoid triggering multiple buttons or reaching across one button location to press another.

MeterView XL Programming Software



The fastest and easiest way to program the meter is using the free MeterView XL programming software. This software greatly simplifies the programming process and allows the user to save configuration files for later use.

The meter connects to the PC via a provided micro-USB cable and is powered by the USB connection, so no additional power is needed during programming.

To download the latest MeterView XL programming software and manual, visit predig.com/meterviewxl.

WARNING

- The meter should only be connected to a computer while it is located in a safe area.

CAUTION

- Care should be exercised to avoid ground loops when connecting the USB to an active loop (e.g. power supply, transmitter, loop-powered meter, etc.). It is recommended to connect the (mA+) terminal of the meter to the (-) terminal of a two-wire transmitter and the (mA-) to the (+) of the next device in the loop or to the (-) terminal of the power supply.



CapTouch Buttons and Status Indicators



Buttons

| Button | Description |
|--------|----------------|
| | Menu |
| | Right Arrow/F1 |
| | Up Arrow/F2 |
| | Enter/F3 |

1. Press the **Menu** button to enter or exit the Programming Mode at any time.
2. Press or hold the **Right-Arrow** button to scroll forward through the menus, select digits during numeric programming, select characters during text programming, or decrement the value of a digit or character selected with the **Up-Arrow** button.
3. Press and hold the **Right-Arrow** button to zero or clear digits/characters while in data-entry mode.
4. Press or hold the **Up-Arrow** button to scroll backwards through the menus or to increment the value of a digit or character.
5. Press the **Enter** button to access a menu or to accept a setting or programmed digit/character value.

Indicators

| Indicator | State | Description |
|-----------|----------|--|
| | Steady | Process trend arrows |
| | Flashing | Alarm Indicator |
| | Steady | Password protected |
| | Steady | Solid-state relay 1 |
| | Steady | Solid-state relay 2 |
| | Flashing | CapTouch buttons self-calibrating (wait) |
| | Dynamic | Bargraph percentage value reading |
| | Steady | PV bargraph |
| | Flashing | Alarm condition: Bargraph segment flashes on alarm |
| | Steady | Feet value |
| | Steady | Inches value |
| | Steady | 8 th of an inch value |
| | Steady | 16 th of an inch value |

Units

| Display | Units |
|---------|--|
| Bottom | lb, m ³ , ton, bbl, ft ³ kg, US GAL, IGAL, GAL |

CAUTION

- Avoid touching more than one button at a time, otherwise the buttons become unresponsive and enter into a self-calibrating routine. This is indicated by the flashing hand symbol

Display Functions & Messages

The meter displays various functions and messages during setup, programming, and operation. The following table shows the main menu functions and messages in the order they appear in the menu.

| Display Functions & Messages | |
|------------------------------|---|
| Parameter | Action/Setting Description |
| INPUT (PV 1 and PV 2) | Program the meter 4-20 mA input (two menus, PV 1 and PV 2, are available if in dual-scale mode; see PV 2 under advanced features menu) |
| UNITS | Set the scaling units. PV/PV1: The meter can be scaled in any height units but will always be displayed in feet and inches. The value will automatically be converted to feet and inches. PV2: See <i>Available Unit Classes and Units</i> on page 34 |
| INCH | Inches |
| FEET | Feet |
| FT-IN | Feet & Inches |
| YARD | Yards |
| CM | Centimeters |
| M | Meters |
| INPUT 1 | Program input 1 value |
| DISP 1 | Program display 1 value |
| INPUT 2 | Program input 2 value (up to 32 points) |
| DISP 2 | Program display 2 value (up to 32 points) |
| SAVE? | Press Enter to save programmed units, input, and display values. Press Menu to cancel. |
| OUTPUT | Program the meter's available outputs |
| OPEN COLLECTR | Program the meter's open collector outputs |
| OUTPUT 1 | Open collector 1 setup |
| OUTPUT2 | Open collector 2 setup |
| DISABLE | Disable the open collector |
| PULSE | Program the open collector for pulse output |
| ALARM | Program the open collector for alarm output |
| TIMER | Program the open collector as a timer |
| STPWATCH | Program the open collector to turn on while the stopwatch is running |
| MESSAGE | Select ON to display a message when open collector is on |
| RELAY | Program the meter's relay outputs |
| OUTPUT 1 | Relay 1 setup |
| OUTPUT2 | Relay 2 setup |

Display Functions & Messages

| Parameter | Action/Setting Description |
|------------------------|---|
| DISABLE | Disable the relay |
| ALARM | Program relay for alarm functionality |
| PUMPCTRL | Program relay for pump control application |
| TIMER | Program relay as a timer |
| STPWATCH | Program relay to turn on while the stopwatch is running |
| MESSAGE | Select ON to display a message when relay is on |
| RELAY INFO | View relay runtime and cycle count |
| 4-20 MA | Program the meter's 4-20 mA output |
| PV | Program a range to transmit based on the display value |
| RETRANS | Retransmit the mA input signal |
| DISABLE | Disable the 4-20 mA output |
| CONTROL | Program manual or automatic operation for the outputs |
| OC 1 | Open collector 1 |
| OC2 | Open collector 2 |
| RELAY 1 | Relay 1 |
| RELAY2 | Relay 2 |
| 4-20 mA | 4-20 mA output |
| AUTO | Set selected output to automatic operation |
| MANUAL | Manually control selected output operation |
| ADVANCE | Program the meter's advanced features |
| PV SETUP (PV 1 & PV 2) | Advanced input programming (two menus, PV 1 and PV 2, are available if in dual-scale mode; see PV 2 under advanced features menu) |
| SOURCE | Select PV 2 source (dual-scale only; see PV 2 under advanced features menu) |
| 4-20 mA | Source PV 2 from the mA input |
| PV 1 | Source PV 2 from PV 1 |
| FUNCTN | Select linear or round horizontal tank (PV2 only) |
| LINEAR | Set meter for linear function and select number of linearization points |
| RH TANK | Round horizontal tank (dual-scale only; see PV 2 under advanced features menu) |
| SCALECAL | Scale or calibrate the mA input |
| SCALE PV (1 or 2) | Scale the input |
| CAL PV (1 or 2) | Calibrate the input |
| CUTOFF | Set low-height cutoff |

| Display Functions & Messages | |
|------------------------------|--|
| Parameter | Action/Setting Description |
| DISABLE | Disable low-height cutoff |
| ENABLE | Enable low-height cutoff |
| FILTER | Set noise filter value |
| 10 SEC | 1 second |
| 20 SEC | 2 seconds |
| 40 SEC | 4 seconds |
| 80 SEC | 8 seconds |
| 160 SEC | 16 seconds |
| OFF | Turn filter off |
| BYPASS | Set filter bypass (0.0 to 99.9% FS) |
| PASSWRD | Set a password for the meter |
| USER | Assign function keys / digital input |
| F1 | Assign F1 function key |
| F2 | Assign F2 function key |
| F3 | Assign F3 function key |
| DI | Assign digital input |
| DISP FN | Set the function key or digital input to display a value |
| DISPLAY | Cycle max, min, and PV(s) |
| DISP PV | Display the PV |
| PCT PV | Display the PV's percentage of max (20 mA) |
| UNITS | Display the PV's units |
| TAG | Display the PV's tag |
| DISP MIN | Display the PV's minimum value |
| DISP MAX | Display the PV's maximum value |
| MIN MAX | Display the PV's minimum and maximum value |
| mA IN | Display the current mA input value |
| mA OUT | Display the current mA output value |
| MENU FN | Set the function key or digital input to access a menu |
| RLY INFO | Go to relay information menu (INFO) |
| MANCTRL | Go to output control menu (CONTROL) |
| TMR OC1 | Open collector 1 timer |
| TMR OC2 | Open collector 2 timer |
| TMR R1 | Relay 1 timer |
| TMR R2 | Relay 2 timer |
| TIMERFN | Set the function key or digital input to start or stop a timer |
| STARTALL | Start all timers |
| STOPALL | Stop all timers |
| SSTPALL | Start or stop all timers |
| OC1 | Start/stop open collector 1 timer |
| OC2 | Start/stop open collector 2 timer |
| RLY1 | Start/stop relay 1 timer |

| Display Functions & Messages | |
|------------------------------|--|
| Parameter | Action/Setting Description |
| RLY2 | Start/stop relay 2 timer |
| START | Start the selected timer output |
| STOP | Stop the selected timer output |
| STR--STP | Start or stop the selected timer output |
| ALARMFN | Set the function key or digital input to acknowledge an alarm or access set points |
| ACK | Acknowledge all active alarms |
| SETPoint | Access all output set points |
| SETP1 | Access open collector 1 set point |
| SETP2 | Access open collector 2 set point |
| SETR1 | Access relay 1 set point |
| SETR2 | Access relay 2 set point |
| SWATCHFN | Set the function key or digital input to activate stopwatch |
| START | Start the stopwatch |
| STOP | Pause/Stop the stopwatch |
| STR--STP | Start or stop the stopwatch |
| TAREFN | Set the function key or digital input to tare the display |
| TARE | Tare the display value |
| RST TARE | Reset the display value |
| HOLD FN | Set the function key or digital input to hold an output |
| HOLD OUT | Hold all outputs while F1-F3 or DI are active (pressed or on) |
| UNHOLD | Displayed when hold all outputs key is released |
| HL UNHL | Displayed when hold all outputs key is released |
| OC 1+2 | Hold/un-hold open collector outputs |
| RLY 1+2 | Hold/un-hold relay outputs |
| mA OUT | Hold/un-hold 4-20 mA output |
| HOLD | Hold selected output |
| HL UNHL | Hold or un-hold selected output |
| DISABLE | Disable function key or digital input |
| RST FN | Set the function key or digital input to reset a value |
| RESET | Reset min, max, or max/min PV |
| R MINMAX | Reset max and min PV value |
| HINT | Display hint text on key press and execute action on next key press |
| OFF | Turn the hint function off |
| ON | Turn the hint function on |
| SYSTEM | Program system settings |
| ADJCAL | Calibrate the analog output |
| DEFAULT | Load factory defaults |

| Display Functions & Messages | |
|------------------------------|---|
| Parameter | Action/Setting Description |
| PV 2 | Enable the meter to scale a second PV based on the same 4-20 mA input |
| DISABLE | Disable dual-scale feature (default) |
| ENABLE | Enable dual-scale feature |
| BACKLITE | Enable/disable display backlight |
| ENABLE | Enable the backlight (default) |
| DISABLE | Disable the backlight |
| CAPTUCH | Select CapTouch buttons mode |
| NORMAL | CapTouch normal (default) |
| DELAYED | CapTouch delayed |
| INFO | View meter software version and model; change the identifier tag |
| SFT | The software ID number |
| VER | The software version |
| MODEL | The meter model number |
| IDTAG | The meter identifier tag Press <i>Enter</i> to edit tag |
| ICAL | Internal calibration used for scaling |
| DISPLAY | Program the meter's display |
| UNITS | Change the feet and inches display for PV (PV1) or PV2 units if enabled |
| FT-IN/* | Display feet and inches with automatically reducing denominator up to sixteenths of an inch |
| FT-IN/16 | Display feet and inches with sixteenths of an inch |
| FT-IN/8 | Display feet and inches with eighths of an inch |
| FT-IN/4 | Display feet and inches with quarter inches |
| FT-IN/2 | Display feet and inches with half inches |
| FT-IN | Display only feet and inches |
| DECP | Change the decimal point location |
| COMMA | Enable or disable the use of a comma on the bottom display |
| ENABLE | Enable comma (default) |
| DISABLE | Disable comma |
| BARGRAPH | Turn off or change the bargraph |
| PV | Set the bargraph to display the percentage of a user-selected range |
| OFF | Turn off the bargraph |
| PV PCT | Set the bargraph to display the PV percentage of full scale |
| BOTTOM | Select what to display on the bottom display |
| TAG | Display the tag |
| STOPWATCH | Display the stopwatch |
| TIMR OC 1 | Display open collector 1 timer |

| Display Functions & Messages | |
|------------------------------|---|
| Parameter | Action/Setting Description |
| TIMR OC 2 | Display open collector 2 timer |
| TIMER R 1 | Display relay 1 timer |
| TIMER R 2 | Display relay 2 timer |
| MIN | Display minimum value |
| MAX | Display maximum value |
| MIN MAX | Display alternating min and max |
| OFF | Turn bottom display off |
| PV PCT | Display the process variable percentage of full scale |
| mA IN | Display the current mA input value |
| mA OUT | Display the current mA output value |
| UNITS | Display the units |
| PV | Display the process variable |
| PV+UNIT | Display the process variable and unit alternating |
| PV+TAG | Display the process variable and tag alternating |
| TAG+UNIT | Display the tag and unit alternating |
| PV+U+TAG | Display the process variable, unit, and tag alternating |


Note: The order of the selection shown above is for a single scale setup. If PV 2 is enabled in the System – PV 2 menu, the display selections include PV 2. Below is a list of PV 2 display selections.

| | |
|-----------|---|
| PV 2 | Display the PV 2 process variable |
| PV 1+PV 2 | Display both process variables (dual-scale only; see PV 2 under advanced features menu) |
| PV 2+UNIT | Display the PV 2 process variable and unit alternating |
| PV 2+TAG | Display the PV 2 process variable and tag alternating |
| PV 2+U+T | Display the PV 2 process variable, unit, and tag alternating |
| PV 2 PCT | Display the PV 2 process variable percentage of full scale |

Main Menu

The main menu consists of all the meter's programmable functions: *Input*, *Output*, *Advanced*, and *Display*.

- Press **Menu** button to enter *Programming Mode* then press the **Right-Arrow** button to move forward through the menu and the **Up-Arrow** button to move back.
- Press **Menu** at any time to go back one level or press & hold to exit and return to *Run Mode*. Changes made to settings prior to pressing **Enter** are not saved.
- Changes to the settings are saved to memory only after pressing **Enter/F3** to confirm the setting or pressing **Enter/F3** at the **SAVE ?** screen when available.




Note: The navigation returns to the top

Setting Numeric Values

The numeric values are set using the **Right** and **Up-Arrow** buttons.

1. Press **Right-Arrow** to select next digit and **Up-Arrow** to increment digit value. The selected digit will flash.
2. Press and hold **Up-Arrow** to auto-increment the display value. If you have made a mistake or would like to enter a new value, select the left-most digit, and press and hold the **Right-Arrow** button until all digits reset to zero.
3. Press the **Enter** button at any time to accept a setting or **Menu** button to exit without saving changes.

Note: the underscore in the graphic below is provided to show which digit would be flashing.




Note: Selected digit flashes. Flashing digit demonstrated using underscore.
Example: 005

Scaling the 4-20 mA Input (INPUT)

It is **very important** to read the following information before proceeding to program the meter:

- The meter is factory calibrated prior to shipment to display 0.00 to 100.00 FT, which corresponds to the 4-20 mA input. The calibration equipment is traceable to NIST standards.
- A calibrated signal source is not needed to scale the meter.

Enter the *Input* menu to scale the meter to display the 4-20 mA input. The input can accept any signal from 4 to 20 mA.



Available Unit Classes and Units

The process variable (PV) can be scaled in several different height units. No matter the scaling units, the scaled value will be converted to feet & inches for display. The available scaling units for the PV (or PV 1 in dual-scale mode) are:

| | |
|-------|---------------|
| INCH | Inches |
| FEET | Feet |
| FT-IN | Feet & Inches |
| YARD | Yards |
| CM | Centimeters |
| M | Meters |

The meter has six available preprogrammed unit classes when programming PV2: *volume, height, temperature, pressure, weight, and rate*. These units are only available when the meter is in dual-scale mode and PV 2 is being programmed. PV 1 can only be programmed with height units.

Each unit class has the following available units to choose from:

| Volume Units (VOLUME) | |
|-----------------------|------------------|
| GAL | Gallons |
| L | Liters |
| IGAL | Imperial Gallons |
| M3 | Cubic Meters |
| BARREL | Barrels |
| BUSH | Bushels |
| CUB YD | Cubic Yards |
| CUB FT | Cubic Feet |
| CUB IN | Cubic Inches |
| L. BARREL | Liquid barrels |
| BEER BARREL | Beer barrels |
| HECT L | Hectoliter |
| AF | Acre-Foot |
| CUSTOM | Custom Unit |

| Height Units (HEIGHT) | |
|-----------------------|---------------|
| INCH | Inches |
| FEET | Feet |
| FT-IN | Feet & Inches |
| YARD | Yards |
| CM | Centimeters |
| M | Meters |
| CUSTOM | Custom unit |

| Temperature Units (TEMP) | |
|--------------------------|--------------------|
| °F | Degrees Fahrenheit |
| °C | Degrees Celsius |
| K | Kelvin |
| °RA | Degrees Rankine |

| Pressure Units (PRESSURE) | |
|---------------------------|---------------------------------|
| PSI | Pounds per square inch |
| IN HG | Inches of mercury |
| IN H2O | Inches of water |
| mmHG | Millimeters of mercury |
| KG/CM2 | Kilograms per square centimeter |
| KG/M2 | Kilograms per square meter |
| mBAR | Millibar |
| BAR | Bar |
| PA | Pascal |
| hPA | Hectopascal |
| kPA | Kilopascal |
| MPA | Megapascal |
| CUSTOM | Custom unit |


| Weight Units (WEIGHT) | |
|-----------------------|-----------------|
| Gm | Grams |
| KG | Kilograms |
| TonNE | Tonnes (metric) |
| oz | Ounces |
| lb | Pounds |
| Ton | Tons |
| CUSTOM | Custom unit |

| Rate Time Bases (TIME) | |
|------------------------|------------------|
| /SECOND | Units per second |
| /MINUTE | Units per minute |
| /HOUR | Units per hour |
| /DAY | Units per day |

| Rate Units (RATE) | |
|-------------------|------------------------------------|
| GAL / (T) | Gallons per time unit (T) |
| L / (T) | Liters per time unit (T) |
| IGAL / (T) | Imperial gallons per time unit (T) |
| M3 / (T) | Cubic meters per time unit (T) |
| BARREL / (T) | Barrels per time unit (T) |
| BUSH / (T) | Bushels per time unit (T) |
| CUB YD / (T) | Cubic Yards per time unit (T) |
| CUB FT / (T) | Cubic Feet per time unit (T) |
| CUB IN / (T) | Cubic Inches per time unit (T) |
| L. BARREL / (T) | Liquid barrels per time unit (T) |
| BEER BARREL / (T) | Beer barrels per time unit (T) |
| HECT L / (T) | Hectoliter per time unit (T) |
| AF / (T) | Acre-Foot per time unit (T) |
| CUSTOM / | Custom unit per time unit (T) |

Setting the Display Features (DISPLAY)

The meter's display functions may be programmed using the *Display* menu. This menu consists of the following submenus: *Units*, *Decimal Point*, *Comma*, *Bargraph*, *Top*, and *Bottom*.



Changing the Engineering Units (UNITS)

The UNITS menu is used to change how fractional inches are represented. The options are automatically reducing, 1/16, 1/8, 1/4, 1/2 of an inch, or no fractions. The default setting (FT--IN/#) automatically reduces the fraction to the lowest denominator.


When in dual-scale mode, it is possible to change the PV 2 display units within the selected unit class without the need to re-scale the meter. When selecting a new unit from within the DISPLAY menu (e.g. changing from gallons (GAL) to liters (L)), the meter will automatically convert the display values to display the new unit. Enter the UNITS menu, select a new unit of measure from the list of predefined units, and press the **Enter** button. If entering a custom unit (CUSTOM), the input must be scaled using the custom unit.

Changing the Decimal Point (DECPNT)

The decimal point may be set with up to seven decimal places or with no decimal point at all.

Pressing the **Right-Arrow** moves the decimal point one place to the right until no decimal point is displayed, and then it moves to the left most position. Pressing the **Up-Arrow** moves the decimal point one place to the left.

If the dual-scale level feature is selected, the decimal point selections for PV2 are enabled.



Enabling or Disabling Commas on the Bottom Display (COMMA)

The bottom display is set to show a comma separating the thousands and millions place by default if a numeric value is being displayed. This feature can be disabled or enabled using the *Comma* menu.

Note: This menu is only available if the meter is in dual-scale mode.




Display Capabilities Optimization (BOTTOM)

Display Configuration Examples

The bottom display can toggle between a tag and units or if dual-scale mode is used, can display the input in a different scale such as volume. The following graphics show typical configurations:

Top Display: Process Variable


Bottom Display: Toggling Between Volume and Units



Note: To display units as GALLONS, select custom units and enter the desired text.

Top Display: Process Variable

Bottom Display: Toggling Between Volume and Tag




Configuring the Display (BOTTOM)

The bottom display line (BOTTOM) can be programmed to display different values. Use the BOTTOM menu to make these changes. If PV2 is enabled, additional options are available for displaying the second PV on the bottom display.

The bottom display (BOTTOM) can be programmed to display:

- Tag (default)
- Stopwatch
- Open Collector 1 or 2 Timer
- Relay 1 or 2 Timer
- Minimum Process Value
- Maximum Process Value
- Alternating Min & Max Process Values
- Off (Blank)
- PV's Percentage of Full Scale
- The mA Input
- The mA Output
- Units
- Process Value (PV)
- Process Value 2 (dual-scale only; see PV 2 under advanced features menu)
- Alternating PV and Units
- Alternating PV and Tag
- Alternating Tag and Units
- Alternating PV, Units, and Tag



Open Collector Outputs (OPEN COLLECTR)

The meter is equipped with two NPN open collector outputs as a standard feature that may be set up for pulse outputs, alarms, timed pulses, or disabled.

Pulse outputs can be set to transmit the PV value (PV1 or PV2 if meter is in dual-scale mode). Output 2 may be used to generate a quadrature output based on the other open collector output. An output test mode is also selectable to generate pulses at a constant programmable frequency.


Alarms are available based on the PV value or the digital input. The alarm status will show on the display even if the output is not wired.

A timer output (TIMER) turns the open collector on and off at the specified time intervals. The timer can be set as single-shot or continuous timer.

The stopwatch output (STPWATCH) allows the open collector to be manually activated by starting the stopwatch. The stopwatch count can be displayed on the top or bottom display.

The output may be disabled by selecting **DISABLE**.

The Open Collector Outputs are programmed in the following manner:




Pulse Output (PULSE)

The pulse outputs may be programmed to generate a scaled frequency based on the PV and a programmable factor. The factor determines the number of pulses per second generated per unit of measure. For example, if the meter display shows 100 gallons and the factor is set to 2, the number of pulses generated per second would be 200. The maximum frequency is 1,000 Hz.

Setting output 2 to quadrature will duplicate the other open collector output, but lag by 90 degrees out of phase. The other output should be programmed as desired for the quadrature output function and must be a pulse (PULSE) output selection. The quadrature maximum frequency for both outputs is 500 Hz.

The TEST option will output a fixed number of pulses per second based on the FREQ value entered.



Alarm (ALARM)


Alarm outputs may be assigned to the PV or the digital input. When assigned to the PV, the alarm may be set as either a high alarm or a low alarm. Alarm actions (AUTO, AUTOMAN, LATCH, L--CLEAR) determine how and when the alarm should be reset. They operate as follows:

- **Automatic (AUTO):** Alarm will reset automatically once the alarm condition has cleared.
- **Automatic/Manual (AUTOMAN):** Alarm will reset automatically once the alarm condition has cleared but can also be reset using the **Enter** (ACK) button (or whichever function key is set to acknowledge) at any time.
- **Latching (LATCH):** Alarm must be reset manually and can be done so at any time. Press the **Enter** (ACK) button at any time to clear the alarm.
- **Latching with Reset after Clear (L--CLEAR):** Alarm must be reset manually and can only be done so after the alarm condition has cleared. Press the **Enter** (ACK) button after the alarm condition has cleared to reset the alarm.

If the alarm is set to PV, a set and reset point must be programmed. The set point is the display value at which the alarm will turn on and the reset point is the display value at which the alarm will turn off. If the set point is lower than the reset point, the alarm will be a low alarm; if the set point is higher than the reset point, the alarm will be a high alarm. The digital input alarm will trigger whenever the digital input is triggered.

For both the PV and digital input alarms, a delay before the alarm is turned on or off may be set, as well as a fail-safe feature which reverses the on/off operation of the open collectors.

Alarm states will be displayed on the meter even if no open collector output is physically connected. These may include a red LED backlight, flashing PV value (PV alarm only), a programmable alarm message, an alarm indicator ▲, and flashing bargraph segment.



Flashing Red Alarm (RED)

The last two lines in the preceding menu flow chart show how to program the display to turn red, flash, and display a message when an alarm occurs.



Alarm 1 is High Alarm



Alarm 2 is Low Alarm

Timer (TIMER)

The timer output may be set to generate the timed pulse only once (ONESHOT) or continuously (CONT).


The timer output produces a constant width pulse at a constant frequency, if set as continuous timer. Program the *Off Delay* (OFF DELAY) from 1 second to 99 hours 59 minutes and 59 seconds. This is the time it takes from selecting START to turning on the output and for how long the output is off in continuous mode.

Program the *On Time* (ON TIME) for the active low pulse from 1 second to 99 hours 59 minutes and 59 seconds (pulse width). This is the period of time for which the output will remain on.

Select *Start* (START) to begin outputting the constant timed pulse.

Select *Stop* (STOP) to end outputting the constant timed pulse.

Function keys or the digital input may be assigned to start and stop timer functions (see the USER menu in the *Advanced Menu*).



Stopwatch (STPWATCH)

The stopwatch function may be used to manually run and control a process for a specific time interval up to 99 hrs., 59 min, and 59 seconds. The stopwatch function may be assigned to any open collector. There are three settings needed to use the function effectively.

1. Assign stopwatch to either top or bottom display
2. Assign the open collector to control the process (on/off)
3. Assign a function key or digital input to start/stop the stopwatch

Application Example

To maintain consistency of a product, it is necessary to take and test samples at different times throughout the day. The stopwatch function is used to open and close a solenoid valve to know the exact amount of time needed to complete the desired sample. Once this is determined, the timer function can be used to automatically take a sample (batch) based on the time determined using the stopwatch function.

Setup: Assign the following to *Stopwatch Function*

- Bottom display
(see pages 35 & 37 for details how to change the display)
- Relay 1
(see pages 38 & 44 how to change Open Collector and Solid-State Relay functionality)
- F3: Start/Stop
(see pages 58 & 59 for details on how to change the function keys)

Procedure

- Press F3 to start the stopwatch; relay 1 turns on and the process starts running.
- Press F3 to stop the stopwatch; relay 1 turns off and the process stops.
- The bottom display indicates the time it took to complete the sample.

Solid-State Relay Outputs (RELAY)

The meter can be optionally equipped with two solid-state relays that may be set up for alarms, timer, stopwatch, or pump control. Alternatively, they may be disabled.

Alarms are available based on the PV value or the digital input. The alarm status will show on the display even if the output is not wired.

Pump control allows the relay to turn on and off a pump at specified on and off points. This can be done using only one of the relays to control one pump (ON-OFF) or using both relays in tandem to alternate between two pumps (ALTERN).


A timer output (TIMER) turns the relay on and off at the specified time intervals. The timer can be set as single-shot or continuous timer.

The stopwatch output (STOPWATCH) allows the relay to be manually activated by starting the stopwatch. The stopwatch count can be displayed on the top or bottom display.

The output may be disabled by selecting **DISABLE**.

CAUTION

- During setup, the relays do not follow the input and they will remain in the state found prior to entering the Relay menu.



Alarm (ALARM)


Alarm outputs may be assigned to the PV or the digital input. When assigned to the PV, the alarm may be set as either a high alarm or a low alarm. Alarm actions (AUTO, AUTOMAN, LATCH, L-CLEAR) determine how and when the alarm should be reset. They operate as follows:

- **Automatic (AUTO):** Alarm will reset automatically once the alarm condition has cleared.
- **Automatic/Manual (AUTOMAN):** Alarm will reset automatically once the alarm condition has cleared but can also be reset using the **Enter** (ACK) button (or whichever function key is set to acknowledge) at any time.
- **Latching (LATCH):** Alarm must be reset manually and can be done so at any time. Press the **Enter** (ACK) button at any time to clear the alarm.
- **Latching with Reset after Clear (L-CLEAR):** Alarm must be reset manually and can only be done so after the alarm condition has cleared. Press the **Enter** (ACK) button after the alarm condition has cleared to reset the alarm.

If the alarm is set to PV, a set and reset point must be programmed. The set point is the display value at which the alarm will turn on and the reset point is the display value at which the alarm will turn off. If the set point is lower than the reset point, the alarm will be a low alarm; if the set point is higher than the reset point, the alarm will be a high alarm. The digital input alarm will trigger whenever the digital input is triggered.

For both the PV and digital input alarms, a delay before the alarm is turned on or off may be set, as well as a fail-safe feature which reverses the on/off operation of the relays.

Alarm states will be displayed on the meter even if no relay output is physically connected. These may include a red LED backlight, flashing PV value (PV alarm only), a programmable alarm message, an alarm indicator ▲, and flashing bargraph segment.



Pump Control (PUMPCTRL)


The pump control output is used in situations where the relays are used to control pumps. There are two options available for controlling pumps: on-off (ON-OFF) and pump alternation (ALTERN).

ON-OFF will turn the relay on at a programmed on point and off at a programmed off point. Setting the on point higher than the off point will make the output activate on a high PV value; setting the on point lower than the off point will make the output activate on a low PV value. The relay will reset automatically.

For pump control applications where two similar pumps are used to control the level of a tank or a well, it may be desirable to have the pumps operate alternately. This prevents excessive wear and overheating of one pump over the lack of use of the other pump. Pump alternation uses both relays in tandem to alternate between two similar pumps. The ALTERN menu is only available under Output 1 and will automatically set Output 2 to pump alternation as well. Use the pump *Alternation Time* setting (ALTIME) to control the alternation based on runtime in addition to level cycles.

On/Off Pump Control (ON-OFF)

When programming a single pump to turn on and off, the on and off points must be programmed. The relay will activate at the on point and deactivate at the off point. On and off delays may be programmed to delay the activation or deactivation of the relay by a certain number of seconds after reaching either the on point or off point.




Pump Alternation (ALTERN)

Pump alternation sets the two relays to alternate every time the first *on* point (ON 1) is reached. The active relay will turn off once the first *off* point (OFF 1) is reached. If the PV reaches the second *on* point (ON 2), the other relay will also turn on. The second relay will turn off once the second *off* point (OFF 2) is reached and the first relay will remain active until the first *off* point (OFF 1) is reached.

On and off delays may optionally be programmed for each *on* and *off* point to delay the activation or deactivation of the relays by a certain number of seconds after reaching either the *on* point or *off* point.

For pumps that typically remain on extensively, the alternation time (ALTTIME) parameter sets a period of relay on-time after which the relays should alternate. For example, if the alternation time is set to one hour, pump 1 will turn off after one hour of runtime regardless of the level reading, at which point pump 2 becomes the active pump. Pump 2 will run until one hour has passed, or the tank has reached a desirable level; whichever happens first. By using the proper on/off points, the alternation can be set up so that the first pump on is the first pump off. This is desirable when the two pumps are of similar rating.



Pump Control with Alternation & Alarm Example


The following is a typical application where the relays and open collectors are used for pump alternation and high and low level alarm.

Pump and Alarm On & Off Point Programming


| Relay | On Point | Off Point | Function |
|-------|----------|-----------|----------------------|
| 1 | 35 feet | 10 feet | Controls backup pump |
| 2 | 30 feet | 10 feet | Controls main pump |

| OC | On Point | Off Point | Function |
|----|----------|-----------|------------------|
| 1 | 35 feet | 34 feet | Trips high alarm |
| 2 | 5 feet | 6 feet | Trips low alarm |


The following graphics provide a visual representation of a typical pump alternation application:




Relay #2 turns the main pump on at 30 feet and turns it off at 10 feet. **R2** lights up to show relay 2 is energized. The **▲** indicates level is rising.



With the Pump Alternation feature activated, the next time the level reaches 30 feet, relay #1 transfers and starts the backup pump. **R1** lights up to show relay 1 is energized.



If the backup pump is not able to keep up, and the level reaches 35 feet, relay #2 transfers and starts the main pump as well. Open collector #1 trips the High Level Alarm, the display turns red and flashes "Hi Level" message, and **▲** indicates an alarm condition. The High Level Alarm resets at 34 feet.



Once the level has dropped below the reset points, both relays will turn off. If the Main Pump fails to turn off, open collector #2 trips the Low Level Alarm at 5 feet to warn against the pump running dry. The Low Level Alarm resets at 6 feet.


Timer (TIMER)

The timer output may be set to generate the timed pulse only once (ONESHOT) or continuously (CONT). The timer output produces a constant width pulse at a constant frequency, if set as continuous timer.

Program the *Off Delay* (OFF_DELAY) from 1 second to 99 hours 59 minutes and 59 seconds. This is the time it takes from selecting START to turning on the output and for how long the output is off in continuous mode.

Program the *On Time* (ON TIME) for the active low pulse from 1 second to 99 hours 59 minutes and 59 seconds (pulse width). This is the period of time for which the output will remain on.

Select *Start* (START) to begin outputting the constant timed pulse. Select *Stop* (STOP) to end outputting the constant timed pulse. Function keys or the digital input may be assigned to start and stop timer functions (see the USER menu in *Advanced*).



Stopwatch (STOPWATCH)

The stopwatch function may be used to manually run and control a process for a specific time interval up to 99 hrs., 59 min, and 59 seconds. The stopwatch function may be assigned to any relay. There are three settings needed to use the function effectively.

1. Assign stopwatch to either top or bottom display
2. Assign the relay to control the process (on/off)
3. Assign a function key or digital input to start/stop the stopwatch

Application Example

To maintain consistency of a product, it is necessary to take and test samples at different times throughout the day. The stopwatch function is used to open and close a solenoid valve to know the exact amount of time needed to complete the desired sample. Once this is determined, the timer function can be used to automatically take a sample (batch) based on the time determined using the stopwatch function.

Setup: Assign the following to *Stopwatch Function*


- Bottom display
(see pages 35 & 37 for details how to change the display)
- Relay 1
(see pages 38 & 44 how to change Open Collector and Solid-State Relay functionality)
- F3: Start/Stop
(see pages 58 & 59 for details on how to change the function keys)

Procedure

- Press F3 to start the stopwatch; relay 1 turns on and the process starts running.
- Press F3 to stop the stopwatch; relay 1 turns off and the process stops.
- The bottom display indicates the time it took to complete the sample.

Runtime & Cycle Count (INFO)

The relay information menu shows runtime and cycle count for each relay. These values may be cleared at any time by selecting the *Clear* option (CLEAR?).




Isolated 4-20 mA Output (4-20 mA)

The 4-20 mA menu is used to scale the isolated 4-20 mA output based on display values. This menu is not present on models without a 4-20 mA output option.

The 4-20 mA analog output can be scaled to provide a 4-20 mA signal for any PV display range or to simply retransmit the 4-20 mA input. The output may be disabled (DISABLE), and will only output the minimum signal.

Overrange and underrange values determine what mA signal the meter will output if the mA input is underrange (<3.5 mA) or overrange (>20.5 mA). This value may be set to 1 mA, 3.5 mA, 3.8 mA, 20.5 mA, 20.8 mA, 23 mA, or disabled.

No equipment is needed to scale the analog output; simply program two display values and corresponding mA output signals.



Process Variable (PV)

To scale the analog output, enter display value 1 and a corresponding analog output value for this display, and enter display value 2 and a corresponding analog output value for this display value. This will provide a scaled linear analog output.


Retransmit (RETRANS)

This option will retransmit the 4-20 mA analog input without the need to scale the output.

Output Manual Control (CONTROL)


The *Control* menu is used to control the open collector outputs, 4-20 mA analog output, and the relays manually, ignoring the input. Each open collector, relay, and analog output can be programmed independently for manual control. Selecting automatic control sets all relays and analog output for automatic operation.

After selecting manual control for a specific output, you can set the output value. To change the output value, return to the Control menu, select the output to control, select manual control, and enter a new value.




Advanced Features Menu (ADVANCE)

To simplify the setup process, functions not needed for most applications are located in the *Advanced Features* menu. The options under advanced features include *advanced PV setup, cutoff, filter, password, function key programming, and system settings.*



Advanced Process Variable Setup (ADV PV)

The Advanced PV Setup menu contains options to apply input signal conditioning functions to the input and to scale/calibrate the input signal.




Input Signal Conditioning Functions (FUNCTN)

The *Function* menu is used to select the input signal conditioner applied to the input: linear, square root, programmable exponent, or round horizontal tank volume calculation. Multi-point linearization is part of the linear function selection.

Meters are set up at the factory for linear function with 2-point linearization. The linear function provides a display that is linear with respect to the input signal.


To use the PV 2 functions, PV 2 must be enabled in the System - PV 2 menu.



* Available for PV2 only

Using MeterView XL


MeterView XL makes programming the input signal conditioning functions quick and easy. Go to the input/scale menu and select the desired function from the drop down menu in the “scale input” section.




Multi-Point Linearization (LINEAR)

Up to 32 linearization points can be selected for PV1 and PV2 under the LINEAR function. Multi-point linearization can be used to linearize the input so the meter can display volume from non-linear tanks or to convert level to flow using weirs and flumes with complex equations. These points are established via direct entry (SCALE) or with a live calibration signal source (CAL).

If the dual-scale level feature has been selected, the menus for PV1 & PV2 are enabled.





MeterView XL showing the linear points setup feature. Up to 32 points can be selected for PV1 and PV2.




Round Horizontal Tank Linearization (RH TANK)

This function automatically calculates the volume in a round horizontal tank with flat ends. It is only available for PV2 while the meter is in dual-scale mode.

Select units (feet, inches, or cm) for the tank dimensions. Enter the diameter and the length in feet & inches or cm and the results will be calculated automatically in US gallons or liters. The unit of measure for the volume can be changed using the display menu. See *Changing the Engineering Units (UNITS)* on page 36 and *Available Unit Classes and Units* on page 34 for a list of available volume units. There is no need to enter scaling values.



MeterView XL Round Horizontal Tank Function Automatically Calculates the Volume Once the Diameter and the Length of the Tank are Entered.



PD6907 Displaying Height in Feet and Volume in Gallons in a Round Horizontal Tank Using the Round Horizontal Tank Linearization Feature.

Advanced Scaling and Calibration (SCALECAL)

This menu offers options to scale or calibrate the meter.

Scaling the Input (SCALE)

The scale menu in the *Advanced* menu is the same as the scale menu in the *Input* menu. See *Scaling the 4-20 mA Input (INPUT)* on page 33 for details about scaling the meter.


Calibrating the Input (CAL)

To scale the meter without a signal source, refer to *Scaling the 4-20 mA Input (INPUT)* on page 33.

The meter can be calibrated to display the process in engineering units by applying the appropriate input signal and following the calibration procedure. The **CAL** menu can be used either with a calibrated current source or with a live signal coming from a 4-20 mA transmitter connected to the process being measured.

During calibration, the mA input value will be displayed as **INP 1** and **INP 2**. Adjust the input source until the desired mA value is shown.

The use of a calibrated signal source is required.



Follow these steps to calibrate the input:

1. After accessing the **SCALECAL** menu, press the **Right-Arrow** button to scroll to the *Calibration* menu (**CAL PV**) and press **Enter**.
2. Select the appropriate units for the desired process variable, then press **Enter**. For information on units, see *Available Unit Classes and Units* on page 34.
3. The meter displays **INP 1**. Apply a known signal and press **Enter**. The display will flash while accepting the signal.
4. After the signal is accepted, the meter displays **DISP 1**. Enter a corresponding display value for the input signal, and press **Enter** to accept.
5. The meter displays **INP 2**. Apply a known signal and press **Enter**. The display will flash while accepting the signal.
6. After the signal is accepted, the meter displays **DISP 2**. Enter a corresponding display value for the input signal and press **Enter** to accept.
7. After completing calibration, the **SAVE?** display will need to be acknowledged using the **Enter** key before calibration will take effect.

Note: The **SAVE?** prompt is not displayed if no changes have been made to the scaling.

Low-Height Cutoff (CUTOFF)

The low-height cutoff feature allows the meter to be programmed so that the often-unsteady output from a differential pressure transmitter at low flow rates always displays zero on the meter. The cutoff value may be programmed from 0.1 to 99999. The meter will display zero below the cutoff value. The cutoff can be disabled to display negative values.

Noise Filter (FILTER)

The noise filter is available for unusually noisy signals that cause an unstable process variable display. The noise filter averages the input signal over a certain period of time. The filter level determines the length of time over which the signal is averaged. The filter level can be set between 1 and 16 seconds or turned off. The higher the filter level, the longer the averaging time and so the longer it takes the display to settle to its final value. Setting the filter level to off disables the filter function.


Noise Filter Bypass (BYPAS)

The noise filter bypass changes the behavior of the meter so that small variations in the signal are filtered out but large abrupt changes in the input signal are displayed immediately. The bypass value determines the minimum amount of signal change to be displayed immediately. All signal changes smaller than the bypass value are filtered or averaged by the meter. The noise filter bypass may be set between 0.1 and 99.9% of full scale.

Enabling Password Protection (PASSWR)

The *Password* menu is used for programming security to prevent unauthorized changes to the programmed parameter settings.

To set a password, enter the *Password* menu and program a five-digit password. When a password has been enabled, the lock icon  will display in the upper-left side of the display. For instructions on how to program numeric values see *Setting Numeric Values* on page 32.



Making Changes to a Password Protected Meter

If the meter is password protected, the meter will display the message `LOCKED` when the *Menu* button is pressed. Press the *Enter* button while the message is being displayed and enter the correct password to gain access to the menu. After exiting *Programming Mode*, the meter returns to its password protected condition.

Disabling Password Protection

To disable password protection, access the *Password* menu and clear the entered password either by pressing and holding the *Right Arrow* button until all digits reset to zero or manually changing all the digits to zero. When the *Enter* button is pressed, the meter will display `UNLOCK` and will no longer require a password to access *Programming Mode*.

Note: If the meter is password protected and the password has been forgotten, the password may be overridden using the master password: **50865**

Function Keys & Digital Input Available Settings

Refer to the following table for descriptions of each available function key or digital input setting.

| Display | Description |
|-----------|--|
| DISP FN | Set the function key or digital input to display a value |
| DISPLAY | Cycle max, min, and PV(s) |
| DISP PV | Display the PV |
| PCT PV | Display the PV's percentage of max (20 mA) |
| UNITS | Display the PV's units |
| TAG | Display the PV's tag |
| DISPMIN | Display the PV's minimum |
| DISPMAX | Display the PV's maximum |
| MIN MAX | Display the PV's minimum and maximum value |
| mA IN | Display the mA input value |
| mA OUT | Display the mA output value |
| MENU FN | Set the function key or digital input to access a menu |
| RLY INFO | Go to relay information menu (INFO) |
| MANCTRL | Go to output control menu (CONTROL) |
| TMR OC 1 | Open collector 1 timer |
| TMR OC 2 | Open collector 2 timer |
| TMR R 1 | Relay 1 timer |
| TMR R 2 | Relay 2 timer |
| TIMERFN | Set the function key or digital input to start or stop a timer |
| STARTALL | Start all timers |
| STOPALL | Stop all timers |
| SSTPALL | Start or stop all timers |
| OC 1 | Start/stop open collector 1 timer |
| OC 2 | Start/stop open collector 2 timer |
| RLY 1 | Start/stop relay 1 timer |
| RLY 2 | Start/stop relay 2 timer |
| START | Start the selected timer output |
| STOP | Stop the selected timer output |
| STR--STP | Start or stop the selected timer output |
| ALARMFN | Set the function key or digital input to acknowledge an alarm |
| ACK | Acknowledge all active alarms |
| SETPPOINT | Set all output set point |
| SETPTOC 1 | Set open collector 1 set point |
| SETPTOC 2 | Set open collector 2 set point |
| SETPTR 1 | Set relay 1 set point |
| SETPTR 2 | Set relay 2 set point |
| SWATCHFN | Set the function key or digital input to activate stopwatch |

| Display | Description |
|----------|---|
| START | Start the stopwatch |
| STOP | Pause/Stop the stopwatch |
| STR--STP | Start or stop the stopwatch |
| TAREFN | Set the function key or digital input to tare the display value |
| TARE | Tare the display value |
| RST TARE | Reset the display value |
| HOLD FN | Set the function key or digital input to hold an output |
| HOLD OUT | Hold all outputs |
| HL UNHLD | Hold or un-hold all outputs |
| OC 1+2 | Hold/un-hold open collector outputs |
| RLY 1+2 | Hold/un-hold relay outputs |
| mA OUT | Hold/un-hold 4-20 mA output |
| HOLD | Hold selected output |
| HL UNHLD | Hold or un-hold selected output |
| DISABLE | Disable the function key or digital input |
| RST FN | Set the function key or digital input to reset a value |
| RESET | Reset min, max, or max/min PV value |
| R MINMAX | Reset max and min PV value |

Enabling the Function Key Hint Feature (HINT)

Enabling the function key hint feature will cause a hint message to be displayed when pressing the F1, F2, or F3 function keys. This text gives a brief description of what the button is programmed to do. Pressing that function key a second time will execute that action.

The hint feature does not affect the digital input (DI) which is intended for immediate execution.

Tare (TARE)

The tare function zero's out the display. In the case of scale weight, tare is used to eliminate container weight and provide net weight readings. There are two tare functions; Tare and Reset Tare. When the tare function is used, the display reading is offset by the displayed amount to make the displayed value zero. Reset tare removes the display offset of the net value, and the gross and net values become the same until a new capture tare is entered.


Program a function key or the digital input for the tare and reset tare.



Changing System Settings (SYSTEM)

The System menu contains the following menus: *Analog Output Calibration, Restore Factory Defaults, Dual-Scale (PV2), Backlight, CapTouch Buttons Operation Mode, Information, and Internal Calibration.*

Note: The Analog Output Calibration menu is available only if the option is installed.




Analog Output Calibration (ROUTCAL)

To perform the analog output calibration, it is recommended to use a milliamp meter with a resolution of at least 0.1 μ A to measure the output current. The values saved internally during this procedure are used for scaling the 4-20 mA output in the *Setup* menu.

4-20 mA Output Calibration Procedure

1. Go to the *Advanced Features* menu and navigate to the **SYSTEM** menu and press Enter. Navigate to **ROUTCAL** and press Enter.
2. The display will show 4 mA. The ProtEX+ mA output should now be close to 4 mA. Enter the actual value read by the digital mA meter on the bottom display and press Enter.
3. The display will show 20 mA. The ProtEX+ mA output should now be close to 20 mA. Enter the actual value read by the digital mA meter on the bottom display and press Enter.
4. The ProtEX+ will now calculate the calibration factors and store them.
5. Press Menu to exit.

Enabling the Dual-Scale Feature (PV2)



Dual-Scale Mode

Top Display: Toggling Between Process Variable and Units
Bottom Display: Toggling Between Process Variable (in different scale) and Different Units

For some level applications, such as displaying the height and volume of a tank, a second PV can be enabled which can be scaled to display a different value based on the same 4-20 mA input. This is accomplished by enabling the dual-scale feature (PV2).

When the dual-scale feature is enabled, additional menus will be displayed to allow for the programming of the second PV. The input menu will display PV1 and PV2 for scaling and the display menu will allow both PVs to be displayed on either top or bottom display, for example. See *Display Functions & Messages* on page 28 for additional information on where additional dual-scale specific menus will appear.

PV2 must be enabled to use the Round Horizontal Tank feature. See *Round Horizontal Tank Linearization (RH TANK)* on page 55.

For instructions on how to enable PV2 see *Changing System Settings (SYSTEM)* on page 60.

Enabling or Disabling the Backlight (BACKLITE)

The backlight may be enabled or disabled using the System - Backlight menu. The backlight is enabled by default, but the input must be wired appropriately for the backlight to function. See *Wiring Diagrams* on page 23.

CapTouch Buttons Operation Mode (CAPTOUCH)

CapTouch buttons have two modes of operation: Normal and Delayed. Delayed mode prevents accidental trigger of the buttons. In the Delayed mode, the buttons enter into a low sensitivity state (sleep) and they ignore quick button presses after 20 seconds of inactivity. To wake up the buttons, press and hold any button for more than 2 seconds, the buttons respond normally.

Viewing System Information (INFO)

System information, such as software (firmware) number and version, model number, and system tag, may be viewed in the INFO menu. Press the *Right Arrow* button to cycle through all available meter information. Press *Menu* to go back to the previous menu.

Calibrating the Internal mA Reference (ICAL)

The meter is factory calibrated prior to shipment to display 0.00 to 100.00, which corresponds to the 4-20 mA input. The calibration equipment is traceable to NIST standards.


The use of calibrated signal sources is necessary to calibrate the internal source of the meter. The meter's internal source is what allows the user to scale the meter without applying a signal.

Check calibration of the meter at least every 12 months.

Note: Allow the meter to warm up for at least 15 minutes before performing the internal source calibration procedure.

The *Internal Calibration* menu is part of the *Advanced* menu. Internal Calibration is performed as follows:

1. Press the **Menu** button to enter *Programming Mode*.
2. Press the **Up-Arrow** button **twice** and press **Enter** to access the **Advanced** menu.
3. Press the **Up-Arrow** button and press **Enter** to access the **System** menu.
4. Press the **Up-Arrow** button and press **Enter** to access the **ICAL** menu.
5. The meter displays *low* input current message (40000 mA). Apply a 4 mA signal and press **Enter**. The display flashes for a moment while the meter is accepting the low input signal.
6. After the display stops flashing, the display moves to the *high* input calibration (200000 mA). Apply the high input signal and press **Enter**. The display will flash again while the meter is accepting the high input signal.



Meter Operation

The meter is equipped with four CapTouch through-glass buttons. These buttons allow meter operation without removing the cover and exposing the electronics in a hazardous area.

Three CapTouch buttons labeled F1, F2, and F3 can be programmed as function keys to perform a variety of meter functions simply by pressing on the glass over the button. These include operation of the tare function, resetting the tare, resetting the meter's relays or open collectors, starting and stopping timers, and displaying max/min values. See *Function Keys & Digital Input Available Settings* on page 59 for a complete list of settings available.

A digital input is available on the meter and it may function in a similar fashion as the function keys to allow remote operation of a single task.

The max & min readings (peak & valley) reached by the process can be displayed either continuously by assigning it to a display line in the *Display* menu, or momentarily by pressing the F1 key (default) or assign it to any of the other function key or the digital input.

Pressing the F1 key cycles through various display values (e.g. max, min); press the Enter key to lock the display in the current process value and press the Enter key again to unlock the display.

The relay information menu shows runtime and cycle count for each relay.

Change the PV2 display units within the selected unit class at any time without the need to re-scale the meter. Select the desired units via the *UNITS* menu in the *DISPLAY* menu, and the meter automatically converts the display values to the new unit of measure.

CapTouch Buttons Operation

| Button | Description (Default Settings) |
|---|--|
|  | Press to enter or exit <i>Programming Mode</i> , view settings, or exit max/min readings |
|  | Press to display max/min readings. |
|  | Press to reset max/min readings. |
|  | Press to acknowledge all manually resettable relays or open collectors. Press to lock/unlock the display value after pressing the F1 key. |

CapTouch Buttons

The PD6907 is equipped with four capacitive sensors that operate as through-glass buttons so that it can be programmed and operated without removing the cover (and exposing the electronics) in a hazardous area.



These buttons can be turned off for security by selecting the *Off* setting on the switch located on the side of the display module, close to the Menu button.

To actuate a button, press one finger to the window directly over the marked button area. When the cover is removed, the CapTouch buttons can be used after the meter completes a self-calibrating routine (hand symbol  flashes). The sensors are disabled when more than one button is pressed, and they will automatically re-enable after a few seconds (hand symbol  off).

CapTouch Button Tips & Troubleshooting

The CapTouch buttons are designed to work under any lighting condition and to protect against false triggering. If the CapTouch buttons are not needed during operation, they can be turned off (slide switch to *Off*).

- To remove cover with power applied (safe area only), or to clean the window, place your hand over the buttons; this will temporarily disable the CapTouch buttons to prevent inadvertent use.
- Keep the glass window clean.
- Tighten the cover securely.
- Use a password to prevent tampering.

IMPORTANT

- CapTouch buttons will not work if two or more buttons are detected as being pressed simultaneously. Be careful to avoid triggering multiple buttons or reaching across one button location to press another.

Function Keys Operation

During operation, the programmable function keys operate according to the way they have been programmed in the *Advanced Features – User* menu. The table under *CapTouch Buttons Operation* on page 62 shows the factory default settings for F1, F2, and F3.

A hint message may be enabled to provide a description of what each function key does prior to executing their assigned function. See *Enabling the Function Key Hint Feature (HINT)* on page 59.

Digital Input Operation

A digital input is standard on the meter. This digital input is programmed identically to function keys F1, F2, and F3. The input is triggered with a contact closure between DI+ and DI-, or with an active low signal. During operation, the digital input operates according to the way it has been programmed in the *Advanced Features – User* menu.

Maximum/Minimum Readings


The max & min readings (peak & valley) reached by the process can be displayed either continuously or momentarily.

Display momentarily by pressing the F1 function key (default) or assigning to any of the other function keys or to the digital input in the *User* menu.

Display continuously by pressing the **Enter** button while the max/min is being displayed to lock the display. Press **Enter** again to unlock.


Any of the F1-F3 function keys (buttons) and the digital input can be programmed to reset the max & min readings. The meters are set at the factory to display the max reading by pressing the *Right Arrow/F1* button and to use the *Up-Arrow/F2* button to access the *Reset* menu. Press the *Right Arrow* button to cycle through the available parameters to reset.

Top Display: Process Value
Bottom Display: Max & Min




Runtime & Cycle Count (INFO)

The relay information menu shows runtime and cycle count for each relay. These values may be cleared at any time by selecting the *Clear* option (CLEAR?). If the cycle count or runtime values need to be changed on a frequent basis, it would be convenient to set up a CapTouch button or the digital input to simplify this process.



Note: See the menu tree under *Solid-State Relay Outputs (RELAY)* on page 44 for complete menu structure on this feature.

| | |
|--|---|
| <p>Meter displaying the amount of time a relay has been activated</p> | <p>Meter displaying the number of times a relay has cycled</p> |
|--|---|



Changing PV2 Engineering Units

It is possible to change PV2's display units within the selected unit class without the need to re-scale the meter. The **UNITS** menu in the **DISPLAY** menu allows the unit of measure to be changed (e.g. from gallons (GAL) to liters (L)) and the meter will automatically convert the display values to the new unit of measure. If entering a custom unit (CUSTOM), the input must be scaled using the custom unit. See *Changing the Engineering Units (UNITS)* on page 36.

Troubleshooting

This product is a highly sophisticated instrument with an extensive list of features and capabilities. If the CapTouch buttons are used to program the meter, it can be a difficult task to keep everything straight. That is why we strongly recommend the use of the free [MeterView XL](#) software for all programming activities. A cable is provided to use the MeterView XL software for programming the meter.


If you have programmed the meter with the CapTouch buttons and it is not working as intended, try re-programming the meter using the MeterView XL software.

Reset Meter to Factory Defaults

When the parameters have been changed in a way that is difficult to determine what's happening, it might be better to start the setup process from the factory defaults. This can be accomplished using MeterView XL software or with the CapTouch buttons.

To load factory defaults:

1. Press the **Menu** button to enter *Programming Mode*.
2. Press the **Right-Arrow** button **twice** and press **Enter** to access the **Advanced** menu.
3. Press the **Up-Arrow** button and press **Enter** to access the **System** menu.
4. Press the **Right-Arrow** button and press **Enter** to access the **Default** menu.
5. Press **Enter** twice in quick succession. The meter will load default settings and restart.



Determining Software Version

To determine the software (firmware) version of a meter:

1. Press the **Menu** button to enter *Programming Mode*.
2. Press the **Up-Arrow** button **twice** and press **Enter** to access the **Advanced** menu.
3. Press the **Up-Arrow** button and press **Enter** to access the **System** menu.
4. Press the **Up-Arrow** button **twice** and press **Enter** to access the **Info** menu.
5. Press the **Right-Arrow** button to cycle through the meter information. When done, press the **Menu** button to return to the previous menu or press & hold **Menu** to exit to Run mode.

Factory Default Settings

The following table shows the factory setting for most of the programmable parameters on the meter.

| Parameter | Display | Default Setting |
|-------------------------|-----------|-----------------|
| Input Menu | | |
| Unit of Measure | UNIT | Feet & Inches |
| Input 1 | INP 1 | 4.000 mA |
| Display 1 | DISP 1 | 0.00 |
| Input 2 | INP 2 | 20.000 mA |
| Display 2 | DISP 2 | 100.00 |
| Output Menu | | |
| Open Collector Output 1 | OUTPUT 1 | Disabled |
| Pulse Factor | FACTOR | 1.0 |
| Test Frequency | FREQ | 100 |
| Alarm | ALARM | PV |
| Alarm Action | ACTION | AUTO |
| Set Point | SET | 20.00 |
| Reset Point | RESET | 10.00 |
| Alarm On Delay | DELAY ON | 0 seconds |
| Alarm Off Delay | DELAY OFF | 0 seconds |
| Alarm Fail-safe | FAILSAFE | OFF |
| Red LED | RED | ON |
| Flash PV | FLASH | ON |
| Alarm Message | MSG | ON |
| Message Text | MSG EDIT | ALARM 1 |
| Timer Off Delay | OFF_DELAY | 1 minute |
| Timer On Time | ON TIME | 1 second |
| Timer Mode | MODE | Continuous |
| Open Collector Output 2 | OUTPUT 2 | Disabled |
| Set Point | SET | 40.00 |
| Reset Point | RESET | 30.00 |
| Message Text | MSG EDIT | ALARM 2 |
| Relay Output 1 | RELAY 1 | Disabled |
| Alarm | ALARM | PV |
| Alarm Action | ACTION | AUTO |
| Set Point | SET | 70.00 |
| Reset Point | RESET | 60.00 |
| Alarm On Delay | DELAY ON | 0 seconds |
| Alarm Off Delay | DELAY OFF | 0 seconds |
| Alarm Fail-safe | FAILSAFE | OFF |
| Red LED | RED | ON |
| Flash PV | FLASH | ON |
| Alarm Message | MSG | ON |
| Message Text | MSG EDIT | ALARM 3 |

| Parameter | Display | Default Setting |
|------------------------------|-------------|-------------------------------------|
| Pump Control Menu | | |
| Pump Ctrl On | ON | 70.00 |
| Pump Ctrl Off | OFF | 60.00 |
| Pump Ctrl On Delay | DELAY ON | 0 seconds |
| Pump Ctrl Off Delay | DELAY OFF | 0 seconds |
| Pump Alt On 1 | ON 1 | 70.00 |
| Pump Alt Off 1 | OFF 1 | 60.00 |
| Pump Alt On 2 | ON 2 | 90.00 |
| Pump Alt Off 2 | OFF 2 | 80.00 |
| Pump Alt On Delay 1 | DELAY 1 ON | 0 seconds |
| Pump Alt Off Delay 1 | DELAY 1 OFF | 0 seconds |
| Pump Alt On Delay 2 | DELAY 2 ON | 0 seconds |
| Pump Alt Off Delay 2 | DELAY 2 OFF | 0 seconds |
| Timer Off Delay | OFF_DELAY | 1 minute |
| Timer On Time | ON TIME | 1 second |
| Timer Mode | MODE | Continuous |
| Relay Output 2 | RELAY 2 | Disabled |
| Set Point | SET | 20.00 |
| Reset Point | RESET | 10.00 |
| Message Text | MSG EDIT | ALARM 4 |
| 4-20 mA Output | 4-20 mA | PV |
| Advanced Menu | | |
| Signal Conditioning Function | FUNCTION | Linear (2 pts) |
| Low Cutoff | CUTOFF | Enabled: 0 |
| Filter | FILTER | 2.0 seconds |
| Filter Bypass | BYPASS | 0.4 PCT |
| Password | PASSWORD | 00000 (Unlocked) |
| Function Key 1 | F1 | Display |
| Function Key 2 | F2 | Reset |
| Function Key 3 | F3 | Acknowledge |
| Digital Input | DI | Acknowledge |
| Hint Feature | HINT | Disabled |
| Dual-Scale | PV 2 | Disabled |
| Backlight | BACKLITE | Enabled |
| CapTouch | CAPT TOUCH | Normal |
| Display Menu | | |
| Unit of Measure | UNITS | FT-IN/* *auto-reducing fractions |
| Bargraph | BARGRAPH | Percent of PV |
| Bottom Display | BOTTOM | Tag (LEVEL) |

Troubleshooting Tips

Certain sequences of events can cause unexpected results. To solve these issues, it is best to start fresh from factory defaults and use the manual as a step by step programming guide, rather than a random approach to programming. To reset the meter to factory defaults, see *Factory Default Settings* on page 65. In addition, for best results, we recommend using the free [MeterView XL](#) software for all programming needs.

| Symptom | Check/Action |
|--|---|
| No display at all | Check: 1. The 4-20 mA current loop is providing at least 3.5 mA to the meter. 2. The voltage drop of all devices connected to the 4-20 mA current loop does not exceed the max rating of the loop power supply. |
| Not able to change setup or programming, LOCK is displayed | Meter is password-protected. Enter correct five-digit password to unlock or Master Password of 50865. |
| Meter display flashes: 1. 99999 2. --9999 | Check that the number of digits required for the scaled value does not exceed the maximum digits for the display. If it does, try adjusting the decimal point location for less precision or changing the PV display to the bottom display. |
| Display is unstable | Check: 1. Input signal stability and value. 2. Display scaling vs. input signal. 3. Filter and bypass values (increase). |
| Display response is too slow | Check filter and bypass values |
| Display reading is not accurate | Check: 1. Input signal conditioner selected: Linear, square root, etc. 2. Scaling or calibration |
| Display does not respond to input changes, reading a fixed number | Check display assignment. It might be displaying max, min, or set point. |
| Display shows: 1. MAX and a number 2. MIN and a number | Press Menu to exit max/min display readings. |
| Relay operation is reversed | Check fail-safe settings in <i>Output</i> menu |
| Relays do not respond to signal | Check: 1. Relay action in <i>Output</i> menu 2. Set and reset points 3. Check manual control menu |
| If the display locks up or the meter does not respond at all | Cycle the power to reboot the microprocessor. |
| CapTouch buttons do not respond | 1. If hand-symbol is flashing, multiple buttons were touch at the same time, wait a few seconds until the hand symbol goes off. 2. If <i>Delayed</i> mode has been set, press & hold any button for 5 seconds, the buttons should respond normally. 3. If the slide switch on the display module is in the Lock position, move the switch to the Unlock position; see <i>Turning Off CapTouch Buttons</i> on page 25. |
| Other symptoms not described above | Call Technical Support for assistance. |

Complete Product Line of Loop-Powered Meters

WITH ALL THE SAME FEATURES & FUNCTIONALITY



2 Open Collector Outputs



2 Solid-State Relays



4-20 mA Output



Two-Color Backlight



Dual-Line Displays



Pump Control



Batch Control



Ex CE IECEx

LARGE DISPLAY

PD4 Loop Leader+ Series

- NEMA 4X, IP65 Rated Wall-Mount Enclosures
- Large 5-Digit, 2.8" High Top Display
- Safe Area and I.S. Models
- ATEX and IECEx Certified



IECEx



IECEx

VantageView+ CE

EXPLOSION-PROOF

PD6900 ProtEX+ Series

- NEMA 4X, IP68 Rated Aluminum and Stainless Steel Enclosures
- CapTouch Through-Glass Buttons
- Explosion-Proof & I.S.
- CSA, ATEX, and IECEx Certified

1/8 DIN PANEL MOUNT

PD6600 Loop Leader Series

- NEMA 4X, IP65 Rated Front 1/8 DIN Panel Mount Meters
- General Purpose and I.S. and N.I. Models
- UL, C-UL, and CE Approved

FIELD-MOUNT

PD6900 VantageView+ Series

- NEMA 4X, IP66 Rated Plastic Enclosure
- CapTouch Through-Window Buttons
- General Purpose



MeterView XL Software Programs All These Products

Go to PREDIG.COM for details

Contact Precision Digital

Technical Support

Call: (800) 610-5239 or (508) 655-7300

Fax: (508) 655-8990

Email: support@predig.com

Sales Support

Call: (800) 343-1001 or (508) 655-7300

Fax: (508) 655-8990

Email: sales@predig.com

Place Orders

Email: orders@predig.com

For the latest version of this manual please visit

www.predig.com

PRECISION DIGITAL CORPORATION

233 South Street • Hopkinton MA 01748 USA

Tel (800) 343-1001 • Fax (508) 655-8990

www.predig.com

