


ALTERNATIVE VIEW

CONTROL INPUTS ARE EASILY DRIVEN BY A RELAY OR TRANSISTOR. THE INPUT ARE ACTIVATED BY CONNECTING THE DESIRED INPUT TO THE NEGATIVE POWER SOURCE. EACH CONTROL INPUT DRAWS 30mA



THE DESIGN AND DISCLOSURE CONTAINED IN THIS DRAWING WAS ORIGINATED BY, AND IS EXCLUSIVE PROPERTY OF A-T CONTROLS, INC. IT IS FURNISHED FOR VENDOR INFORMATION ONLY AND IS NOT AN AUTHORIZATION OR LICENSE TO MAKE THIS CONSTRUCTION OR TO FURNISH THIS INFORMATION TO OTHERS. ALL DRAWINGS MUST BE RETURNED TO A-T CONTROLS, INC. ON DEMAND. THIS DRAWING IS NOT TO BE REPRODUCED OR COPIED IN ANY FORM WITHOUT THE EXPRESS WRITTEN PERMISSION OF A-T CONTROLS, INC.



Division of A-T Controls, Inc.
11363 Deerfield Road
Cincinnati, Ohio 45242
Phone: (513) 247-5465
Fax: (513) 247-5462

DRAWN SAH	CHECKED BY	APPROVED
DATE 05/30/05	DATE	DATE
TITLE WIRING DIAGRAM WE-1350A THRU WE-2640A ELECTRIC ACTUATOR 24VDC		

1565	06/06/14	SAH
ECN#	DATE	BY

