



# Certificate of Compliance

**Certificate:** 2884938

**Master Contract:** 265782

**Project:** 2884938

**Date Issued:** January 21, 2016

**Issued to:** UWT GmbH  
Westendstrasse 5  
Betzigau, 87488  
Germany

**Attention:** Andreas Haug

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only*



*Kim Atkins*

**Issued by:** K. Atkins

## PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT – Miscellaneous Apparatus  
CLASS 3211 87 - INDUSTRIAL CONTROL EQUIPMENT – Miscellaneous Apparatus – Certified to US Standards

Investigation of Level radar transmitter enclosure, Series NR 3000; CSA/UL Enclosure Type 4X, 6 and IP68 (2 metres/24 hours);  $-40^{\circ}\text{C} \leq T_a \leq 80^{\circ}\text{C}$ .

## APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-M91 (R2001)	- General Requirements - Canadian Electrical Code, Part II
CAN/CSA-C22.2 No. 94-M91	- Special Purpose Enclosures
CAN/CSA C22.2 No. 60529:05	- Degrees of Protection Provided by Enclosure
UL Std No. 50 (11 <sup>th</sup> Ed.)	- Enclosures for Electrical Equipment
UL Std. 476C (6 <sup>th</sup> Ed.) - Polymeric Materials	- Use in Electrical Equipment Evaluations (as a guide)
ANSI/IEC 60529-2004	- Degrees of Protection Provided by Enclosures



**Certificate:** 2884938

**Master Contract:** 265782

**Project:** 2884938

**Date Issued:** January 21, 2016

---

## **MARKINGS**

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

The following markings appear silk screened on the enclosure;

Company's name or tradename  
Enclosure series model number or final assembly model number  
Enclosure type designation and/or ingress protection  
CSA Monogram



## *Supplement to Certificate of Compliance*

**Certificate:** 2884938

**Master Contract:** 265782

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

<b>Project</b>	<b>Date</b>	<b>Description</b>		
2884938	January 21, 2016	Original Project No	Model No	Listee Model No
			Series LR500	Series NR 3000